

下宇坂第2(瀬ヶ口)地区 簡易水道

※ “<”は下限値未満 “---”は未検査を表す。単位は記載のない限り“mg/L”とする。

下宇坂第2(瀬ヶ口)地区 簡易水道																	令和 6年 4月 ~ 令和 7年 3月		
項	目	名	施 設	名 称	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日			
採	水	日	水質基準	下限値	晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴			
天	気																		
水	温	(℃)			13.4	20.0	20.9	24.8	30.5	28.5	27.7	18.5	12.9	7.7	6.5	6.6			
水	一 般 細 菌 (集 落 数 /ml)		≦100	0	0	0	0	0	0	0	0	0	0	0	0	0			
	大 腸 菌	不検出			不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出			
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	---	<	---	---	---	---			
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	---	<	---	---	---	---			
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	---	<	---	<	---	---	---	<	---	---	<	---			
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	---	<	---	---	---	---	---	<	---			
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	<	---	<	---	<	---	---	<	---	---	<	---			
	フッ素及びその化合物	≦0.8	0.05	---	0.63	---	---	---	0.62	---	---	0.64	---	---	0.61	---			
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	---	<	---	---	---	---			
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	---	<	---	---	---	---			
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---			
	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	---	<	---	---	---	---			
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
質	ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	塩 素 酸	≦0.6	0.06	---	<	---	---	<	---	---	---	<	---	---	0.08	---			
	ク ロ ロ 酢 酸	≦0.02	0.002	---	<	---	---	<	---	---	---	<	---	---	<	---			
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	<	---	---	---	<	---	---	<	---			
	ジブロモクロロメタン	≦0.1	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	---	<	---	---	<	---			
	ブロモジクロロメタン	≦0.03	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
基	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	---	<	---	---	<	---			
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	---	<	---	---	---	---			
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	---	<	---	---	<	---			
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	---	<	---	---	<	---			
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	---	<	---	---	---	---			
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	---	17.1	---	---	---	---			
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	<	---	---	---	<	---	---	---	---			
	塩 化 物 イ オ ン	≦200	1.0	10.0	10.5	10.1	10.5	10.6	10.2	9.7	9.6	9.3	9.9	10.6	7.5	---			
	カルシウム・マグネシウム等(硬度)	≦300	1	---	127	---	---	---	126	---	---	132	---	---	121	---	---		
単	蒸 発 残 留 物	≦500	1	---	215	---	---	---	224	---	---	223	---	---	202	---	---		
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<	<	<		
	pH 値	5.8~8.6		7.8	7.8	7.9	7.8	7.8	8.0	8.0	7.9	7.8	7.7	7.7	7.7	7.7	7.7		
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
目	色 度 (度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<	<	<		
	濁 度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<	<	<		
残	留	塩 素	≧0.1	0.1	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3		

下宇坂(市波)地区 簡易水道

※ “<”は下限値未満 “---”は未検査を表す。単位は記載のない限り“mg/L”とする。

項目名		施設名称		下宇坂(市波)地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月	
採	水 日	水質基準	下限値	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日		
天	気			晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴		
水	温 (℃)			14.0	19.2	18.5	23.6	24.6	26.0	24.5	19.0	14.1	7.8	6.0	7.3		
水	一般細菌(集落数/㎖)	≦100	0	0	0	0	0	0	0	0	0	0	0	0	0		
	大腸菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出		
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---		
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---		
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	六価クロム化合物	≦0.02	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	亜硝酸態窒素	≦0.04	0.004	<	---	---	---	<	---	---	<	---	---	<	---		
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.32	---	---	0.31	---	---	0.29	---	---	0.36	---		
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	0.05	---		
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---		
	四塩化炭素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---		
	1,4-ジオキサン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---		
	ジクロロメタン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
質	ベンゼン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	塩素酸	≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	<	---		
	クロロ酢酸	≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	クロロホルム	≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	ジクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	ジブロモクロロメタン	≦0.1	0.001	---	---	---	---	<	---	---	<	---	---	<	---		
	臭素酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	ブロモジクロロメタン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
基	ブロモホルム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	ホルムアルデヒド	≦0.08	0.005	---	0.009	---	---	<	---	---	<	---	---	<	---		
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---		
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	<	---	---	<	---		
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	<	---		
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	0.04	---	---	---	---		
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	10.3	---	---	---	---		
	マンガン及びその化合物	≦0.05	0.005	---	<	---	---	<	---	---	<	---	---	<	---		
	塩化物イオン	≦200	1.0	8.4	8.4	8.7	8.7	8.4	8.7	8.3	8.1	8.1	8.7	9.2	7.5		
	カルシウム・マグネシウム等(硬度)	≦300	1	---	80	---	---	74	---	---	73	---	---	73	---		
目	蒸発残留物	≦500	1	---	120	---	---	120	---	---	108	---	---	121	---		
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---		
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---		
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---		
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---		
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<		
	pH値	5.8～8.6		7.4	7.8	7.6	7.7	7.3	7.6	7.4	7.2	7.4	7.2	7.2	7.2		
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	色度(度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<		
	濁度(度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<		
残留塩素	≧0.1	0.1	0.5	0.3	0.4	0.3	0.3	0.3	0.2	0.3	0.3	0.4	0.4	0.6			

下宇坂(三万谷)地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項目名		施設名称		下宇坂(三万谷)地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月	
採	水	日	水質基準	下限値	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日	
天	気				晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴	
水	温	(℃)			12.6	16.5	17.4	20.0	23.5	25.0	22.0	17.5	12.8	8.9	8.4	8.4	
水	一般細菌(集落数/㎖)	≦100	0		0	0	0	0	0	1	0	0	0	0	0	0	
	大腸菌	不検出			不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	
	カドミウム及びその化合物	≦0.003	0.0003		---	---	---	---	---	---	---	<	---	---	---	---	
	水銀及びその化合物	≦0.0005	0.00005		---	---	---	---	---	---	---	<	---	---	---	---	
	セレン及びその化合物	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---	
	鉛及びその化合物	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---	
	ヒ素及びその化合物	≦0.01	0.001		---	0.002	---	---	0.001	---	---	0.001	---	---	0.002	---	
	六価クロム化合物	≦0.02	0.001		---	<	---	---	<	---	---	<	---	---	<	---	
	亜硝酸態窒素	≦0.04	0.004		<	---	---	---	<	---	---	<	---	---	<	---	
	シアン化物イオン及び塩化シアン	≦0.01	0.001		---	<	---	---	<	---	---	<	---	---	<	---	
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10		---	0.45	---	---	0.44	---	---	0.44	---	---	0.45	---	
	フッ素及びその化合物	≦0.8	0.05		---	<	---	---	<	---	---	<	---	---	<	---	
	ホウ素及びその化合物	≦1.0	0.1		---	---	---	---	---	---	---	<	---	---	---	---	
	四塩化炭素	≦0.002	0.0002		---	---	---	---	---	---	---	<	---	---	---	---	
	1,4-ジオキサン	≦0.05	0.005		---	---	---	---	---	---	---	<	---	---	---	---	
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004		---	---	---	---	---	---	---	<	---	---	---	---	
	ジクロロメタン	≦0.02	0.001		---	---	---	---	---	---	---	<	---	---	---	---	
	テトラクロロエチレン	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---	
	トリクロロエチレン	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---	
質	ベンゼン	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---	
	塩素酸	≦0.6	0.06		---	<	---	---	<	---	---	<	---	---	0.10	---	
	クロロ酢酸	≦0.02	0.002		---	<	---	---	<	---	---	<	---	---	<	---	
	クロロホルム	≦0.06	0.001		---	<	---	---	<	---	---	<	---	---	<	---	
	ジクロロ酢酸	≦0.03	0.002		---	<	---	---	<	---	---	<	---	---	<	---	
	ジブロモクロロメタン	≦0.1	0.001		---	<	---	---	<	---	---	<	---	---	<	---	
	臭素酸	≦0.01	0.001		---	<	---	---	<	---	---	<	---	---	<	---	
	総トリハロメタン	≦0.1	0.001		---	<	---	---	<	---	---	<	---	---	<	---	
	トリクロロ酢酸	≦0.03	0.002		---	<	---	---	<	---	---	<	---	---	<	---	
	ブロモジクロロメタン	≦0.03	0.001		---	<	---	---	<	---	---	<	---	---	<	---	
基	ブロモホルム	≦0.09	0.001		---	<	---	---	<	---	---	<	---	---	<	---	
	ホルムアルデヒド	≦0.08	0.005		---	<	---	---	<	---	---	<	---	---	<	---	
	亜鉛及びその化合物	≦1.0	0.01		---	---	---	---	---	---	---	<	---	---	---	---	
	アルミニウム及びその化合物	≦0.2	0.01		---	<	---	---	<	---	---	<	---	---	<	---	
	鉄及びその化合物	≦0.3	0.01		---	<	---	---	<	---	---	<	---	---	<	---	
	銅及びその化合物	≦1.0	0.01		---	---	---	---	---	---	---	<	---	---	---	---	
	ナトリウム及びその化合物	≦200	1.0		---	---	---	---	---	---	---	7.9	---	---	---	---	
	マンガン及びその化合物	≦0.05	0.005		---	<	---	---	<	---	---	<	---	---	<	---	
	塩化物イオン	≦200	1.0		7.8	7.7	8.0	7.7	7.9	8.0	7.8	7.5	7.9	7.8	8.2	14.4	
	カルシウム・マグネシウム等(硬度)	≦300	1		---	46	---	---	46	---	---	47	---	---	46	---	
目	蒸発残留物	≦500	1		---	76	---	---	86	---	---	72	---	---	82	---	
	陰イオン界面活性剤	≦0.2	0.02		---	---	---	---	---	---	---	<	---	---	---	---	
	ジェオスミン	≦0.00001	0.000001		---	---	---	---	---	---	---	<	---	---	---	---	
	2-メチルイソボルネオール	≦0.00001	0.000001		---	---	---	---	---	---	---	<	---	---	---	---	
	非イオン界面活性剤	≦0.02	0.005		---	---	---	---	---	---	---	<	---	---	---	---	
	フェノール類	≦0.005	0.0005		---	---	---	---	---	---	---	<	---	---	---	---	
	有機物等(全有機炭素(TOC)量)	≦3	0.3		<	<	<	<	<	<	<	<	<	<	<	<	
	pH値	5.8～8.6			7.9	7.9	7.9	7.6	7.5	7.6	7.6	7.8	8.0	7.8	7.9	7.9	
	臭	異常でない			異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	
	臭気	異常でない			異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	
	色度(度)	≦5	0.5		<	<	<	<	<	<	<	<	<	<	<	<	
濁	濁度(度)	≦2	0.2		<	<	<	<	<	<	<	<	<	<	<	<	
	残留塩素	≧0.1	0.1		0.4	0.3	0.4	0.3	0.3	0.1	0.2	0.2	0.5	0.3	0.4	0.3	

下宇坂(奈良瀬)地区 簡易水道

※ “<”は下限値未満 “―”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名		施 設 名 称		下宇坂(奈良瀬)地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月	
採 日	日	水質基準	下限値	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日		
天 気				晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴		
水 温 (℃)				12.5	17.5	18.3	22.2	25.2	24.5	23.5	17.5	14.0	10.5	7.5	7.2		
水 質	一 般 細 菌 (集 落 数 /ml)	≦100	0	0	0	0	0	0	0	0	0	0	0	0	0		
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出		
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---		
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---		
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	六価クロム化合物	≦0.02	0.001	---	---	---	---	<	---	---	<	---	---	<	---		
	亜硝酸態窒素	≦0.04	0.004	---	<	---	---	<	---	---	<	---	---	<	---		
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.33	---	---	0.33	---	---	0.33	---	---	0.38	---		
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---		
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---		
	四塩化炭素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---		
	1,4-ジオキサン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---		
	ジクロロメタン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
基 準	ベンゼン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	塩 素 酸	≦0.6	0.06	---	0.08	---	---	<	---	---	<	---	---	<	---		
	クロロ酢酸	≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	クロロホルム	≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	ジクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	ジブロモクロロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	ブロモジクロロメタン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
項 目	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---		
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---		
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	0.01	---	---	<	---		
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	<	---		
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---		
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	10.1	---	---	---	---		
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	塩 化 物 イ オ ン	≦200	1.0	8.6	8.6	8.6	8.8	8.7	8.7	8.3	8.2	8.2	8.8	9.5	8.7		
	カルシウム・マグネシウム等(硬度)	≦300	1	---	83	---	---	80	---	---	84	---	---	85	---		
目	蒸 発 残 留 物	≦500	1	---	124	---	---	116	---	---	120	---	---	130	---		
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---		
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---		
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---		
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---		
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	0.4	<	0.4	<	<	<	<	<		
	pH 値	5.8～8.6		7.9	8.0	8.1	8.0	8.0	8.0	8.1	8.1	8.1	7.8	7.9	7.8		
	臭 味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
残 留 塩 素	色 度 (度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<		
	濁 度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<		
残 留 塩 素		≧0.1	0.1	0.3	0.2	0.3	0.3	0.3	0.2	0.3	0.1	0.1	0.3	0.1	0.1		

宇坂別所地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名		施 設 名 称		宇坂別所地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月			
採 水 日	水質基準	下限値		4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日				
天 気				晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴				
水 温 (℃)				11.6	16.5	18.0	22.1	24.2	24.5	24.5	18.5	12.9	8.0	6.5	7.0				
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	0	3	0	1	0	0	0	0	0	0	0				
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---				
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	亜 硝 酸 態 窒 素	≦0.04	0.004	<	---	---	---	<	---	---	<	---	---	<	---				
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	硝 酸 態 窒 素 及 び 亜 硝 酸 態 窒 素	≦10	0.10	---	0.40	---	---	0.39	---	---	0.44	---	---	0.41	---				
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---				
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---				
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---				
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
質	ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	塩 素 酸	≦0.6	0.06	---	0.12	---	---	<	---	---	<	---	---	0.09	---				
	ク ロ ロ 酢 酸	≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
	ジ ブ ロ モ ク ロ ロ メ タ ン	≦0.1	0.001	---	0.002	---	---	0.002	---	---	0.003	---	---	0.001	---				
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	総トリハロメタン	≦0.1	0.001	---	0.003	---	---	0.002	---	---	0.005	---	---	0.002	---				
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	<	---	---	<	---	---	0.001	---	---	<	---				
基	ブ ロ モ ホ ル ム	≦0.09	0.001	---	0.001	---	---	<	---	---	0.001	---	---	0.001	---				
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	0.01	---	---	0.02	---	---	0.03	---	---	0.02	---				
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	0.01	---	---	0.02	---	---	0.01	---				
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	6.8	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	---	<	---	---	<	---	---	<	---	---	<	---				
	塩 化 物 イ オ ン	≦200	1.0	7.2	7.3	7.1	6.9	7.5	7.4	7.1	7.0	6.7	7.3	7.5	8.2				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	36	---	---	36	---	---	35	---	---	35	---				
目	蒸 発 残 留 物	≦500	1	---	60	---	---	60	---	---	71	---	---	61	---				
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---				
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---				
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<				
	pH値	5.8～8.6		8.0	8.0	7.9	7.7	7.7	7.8	7.7	7.8	7.9	7.8	7.9	7.8				
	臭 味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	色 度 (度)	≦5	0.5	<	<	<	0.6	<	<	<	0.5	<	<	<	<				
濁 度 (度)	≦2	0.2	<	<	0.2	<	<	<	<	0.2	0.2	0.3	<	<					
残 留 塩 素	≧0.1	0.1	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.3	0.2					

皿谷地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名 称			皿谷地区 飲料供給施設												令和 6年 4月 ～ 令和 7年 3月	
採 水 日	水質基準	下限値	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月9日	2月3日	3月10日		
天 気			晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴		
水 温 (℃)			10.4	16.0	16.6	20.5	22.9	26.5	23.5	18.5	12.4	6.5	5.0	5.5		
水	一 般 細 菌 (集 落 数 /ml)	≦100	0	2	0	2	0	1	6	0	1	0	0	0		
	大 腸 菌	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出		
質	カドミウム及びその化合物	≦0.003	0.0003	—	—	—	—	—	—	—	—	—	—	—		
	水銀及びその化合物	≦0.0005	0.00005	—	—	—	—	—	—	—	—	—	—	—		
基	セレン及びその化合物	≦0.01	0.001	—	—	—	—	—	—	—	—	—	—	—		
	鉛及びその化合物	≦0.01	0.001	—	—	—	—	—	—	—	—	—	—	—		
準	ヒ素及びその化合物	≦0.01	0.001	—	—	—	—	—	—	—	—	—	—	—		
	六価クロム化合物	≦0.02	0.001	—	—	—	—	—	—	—	—	—	—	—		
項	亜硝酸態窒素	≦0.04	0.004	—	—	—	—	—	—	—	—	—	—	—		
	シアン化物イオン及び塩化シアン	≦0.01	0.001	—	—	—	—	—	—	—	—	—	—	—		
目	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	—	0.27	—	—	0.27	—	—	0.43	—	—	0.32		
	フッ素及びその化合物	≦0.8	0.05	—	—	—	—	—	—	—	—	—	—	—		
目	ホウ素及びその化合物	≦1.0	0.1	—	—	—	—	—	—	—	—	—	—	—		
	四塩化炭素	≦0.002	0.0002	—	—	—	—	—	—	—	—	—	—	—		
質	1,4-ジオキサン	≦0.05	0.005	—	—	—	—	—	—	—	—	—	—	—		
	1,2-ジクロロエチレン及び1,1,2,2-テトラクロロエチレン	≦0.04	0.004	—	—	—	—	—	—	—	—	—	—	—		
基	ジクロロメタン	≦0.02	0.001	—	—	—	—	—	—	—	—	—	—	—		
	テトラクロロエチレン	≦0.01	0.001	—	—	—	—	—	—	—	—	—	—	—		
準	トリクロロエチレン	≦0.01	0.001	—	—	—	—	—	—	—	—	—	—	—		
	ベンゼン	≦0.01	0.001	—	—	—	—	—	—	—	—	—	—	—		
項	塩 素 酸	≦0.6	0.06	—	0.06	—	—	—	—	—	—	—	—	0.06		
	クロロ酢酸	≦0.02	0.002	—	—	—	—	—	—	—	—	—	—	—		
目	クロロホルム	≦0.06	0.001	—	—	—	—	—	—	—	—	—	—	—		
	ジクロロ酢酸	≦0.03	0.002	—	—	—	—	—	—	—	—	—	—	—		
準	ジブロモクロロメタン	≦0.1	0.001	—	—	—	—	—	—	—	—	—	—	—		
	臭 素 酸	≦0.01	0.001	—	—	—	—	—	—	—	—	—	—	—		
項	総トリハロメタン	≦0.1	0.001	—	—	—	—	—	—	—	—	—	—	—		
	トリクロロ酢酸	≦0.03	0.002	—	—	—	—	—	—	—	—	—	—	—		
目	ブロモジクロロメタン	≦0.03	0.001	—	—	—	—	—	—	—	—	—	—	—		
	ブ ロ モ ホ ル ム	≦0.09	0.001	—	—	—	—	—	—	—	—	—	—	—		
質	ホルムアルデヒド	≦0.08	0.005	—	—	—	—	—	—	—	—	—	—	—		
	亜鉛及びその化合物	≦1.0	0.01	—	—	—	—	—	—	—	—	—	—	—		
項	アルミニウム及びその化合物	≦0.2	0.01	—	—	—	—	—	—	—	0.02	—	—	0.02		
	鉄及びその化合物	≦0.3	0.01	—	—	—	—	—	—	—	0.01	—	—	0.05		
目	銅及びその化合物	≦1.0	0.01	—	—	—	—	—	—	—	—	—	—	—		
	ナトリウム及びその化合物	≦200	1.0	—	—	—	—	—	—	—	5.9	—	—	—		
準	マンガン及びその化合物	≦0.05	0.005	—	—	—	—	—	—	—	—	—	—	—		
	塩 化 物 イ オ ン	≦200	1.0	5.8	5.7	5.8	5.6	5.7	5.9	5.9	5.4	4.9	5.8	6.1	6.2	
目	カルシウム・マグネシウム等(硬度)	≦300	1	—	40	—	—	39	—	—	36	—	—	40		
	蒸 発 残 留 物	≦500	1	—	54	—	—	59	—	—	62	—	—	59		
質	陰イオン界面活性剤	≦0.2	0.02	—	—	—	—	—	—	—	—	—	—	—		
	ジエオスミン	≦0.00001	0.000001	—	—	—	—	—	—	—	—	—	—	—		
項	2-メチルイソボルネオール	≦0.00001	0.000001	—	—	—	—	—	—	—	—	—	—	—		
	非イオン界面活性剤	≦0.02	0.005	—	—	—	—	—	—	—	—	—	—	—		
目	フェノール類	≦0.005	0.0005	—	—	—	—	—	—	—	—	—	—	—		
	有機物等(全有機炭素(TOC)量)	≦3	0.3	—	—	—	—	—	—	—	—	—	—	—		
準	pH 値	5.8～8.6	—	7.6	7.8	7.7	7.3	7.7	7.7	6.9	6.5	7.2	7.5	7.2		
	臭 気	異常でない	—	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
目	色 度 (度)	≦5	0.5	—	—	—	—	—	—	—	—	—	—	—		
	濁 度 (度)	≦2	0.2	—	—	—	—	—	—	—	—	—	—	—		
残 留 塩 素	≧0.1	0.1	0.4	0.3	0.4	0.4	0.2	0.2	0.3	0.3	0.1	0.3	0.2	0.4		

西中地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名			施 設 名 称			西中地区 飲料供給施設										令和 6年 4月 〜 令和 7年 3月			
採 水 日	水質基準	下限値	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日					
天 気			晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴					
水 温 (℃)			12.2	15.0	16.1	19.4	21.5	24.5	24.2	17.5	11.9	4.3	6.2	7.3					
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	28	1	2	3	2	2	0	9	3	0	1					
	大 腸 菌	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出					
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	<	---	---	---	---					
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	<	---	---	---	---					
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---					
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---					
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---					
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	<	---	<	---	---	<	---					
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	<	---	<	---	---	<	---					
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---					
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.81	---	---	0.83	---	---	1.08	---	---	0.87	---				
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	<	---	---	<	---					
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	<	---	---	---	---					
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	<	---	---	---	---					
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	<	---	---	---	---					
	質	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	<	---	---	---	---				
ジ ク ロ ロ メ タ ン		≦0.02	0.001	---	---	---	---	---	---	<	---	---	---	---					
テトラクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---					
トリクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---					
ベ ン ゼ ン		≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---					
塩 素 酸		≦0.6	0.06	---	<	---	---	<	---	<	---	---	<	---					
ク ロ ロ 酢 酸		≦0.02	0.002	---	<	---	---	<	---	<	---	---	<	---					
ク ロ ロ ホ ル ム		≦0.06	0.001	---	<	---	---	<	---	<	---	---	<	---					
ジ ク ロ ロ 酢 酸		≦0.03	0.002	---	<	---	---	<	---	<	---	---	<	---					
ジ ブ ロ モ ク ロ ロ メ タ ン		≦0.1	0.001	---	<	---	---	<	---	<	---	---	<	---					
臭 素 酸		≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---					
総トリハロメタン		≦0.1	0.001	---	<	---	---	<	---	<	---	---	<	---					
トリクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	<	---	---	<	---					
ブ ロ モ ジ ク ロ ロ メ タ ン		≦0.03	0.001	---	<	---	---	<	---	<	---	---	<	---					
ブ ロ モ ホ ル ム		≦0.09	0.001	---	<	---	---	<	---	<	---	---	<	---					
基		ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	<	---	---	<	---				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	<	---	---	---	---					
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	0.02	---	---	<	---					
	鉄 及 び そ の 化 合 物	≦0.3	0.01	---	<	---	---	<	---	<	---	---	<	---					
	銅 及 び そ の 化 合 物	≦1.0	0.01	---	---	---	---	---	---	<	---	---	---	---					
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	6.9	---	---	---	---					
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	<	---	---	---	---					
	塩 化 物 イ オ ン	≦200	1.0	6.5	6.5	6.7	6.3	6.3	6.4	6.3	6.0	5.9	6.5	7.4	7.3				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	59	---	---	64	---	---	66	---	---	63	---				
	蒸 発 残 留 物	≦500	1	---	80	---	---	86	---	---	96	---	---	86	---				
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	<	---	---	---	---	---				
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	<	---	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	<	---	---	---	---	---				
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	<	---	---	---	---	---				
	フ ェ ノ ー ル 類	≦0.005	0.0005	---	---	---	---	---	---	<	---	---	---	---	---				
	項	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<			
pH 値		5.8～8.6		7.5	7.5	7.5	7.5	7.5	7.4	7.4	7.3	7.3	7.6	7.4	7.5				
味		異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
臭 気		異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
色 度 (度)		≦5	0.5	0.5	<	<	<	<	<	<	<	<	<	<	<				
濁 度 (度)		≦2	0.2	1.1	<	<	<	<	<	<	<	<	<	<	<				
目		残 留 塩 素	≧0.1	0.1	<	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.2			

美山大谷地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名		施 設 名 称		美山大谷地区 飲料供給施設												令和 6年 4月 ～ 令和 7年 3月		
採 水 日		水質基準	下限値	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日			
天 気				晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴			
水 温 (℃)				11.2	16.5	17.6	23.2	25.4	26.5	24.6	18.5	9.5	3.4	5.0	5.5			
水	一 般 細 菌 (集 落 数 /ml)	≦100	0	0	0	1	0	0	1	0	0	0	0	0	0			
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出			
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---			
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---			
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	六価クロム化合物	≦0.02	0.001	---	---	---	---	<	---	---	<	---	---	<	---			
	亜硝酸態窒素	≦0.04	0.004	---	<	---	---	<	---	---	<	---	---	<	---			
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.44	---	---	0.43	---	---	0.48	---	---	---	0.53			
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---			
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---			
	四塩化炭素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---			
	1,4-ジオキサン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---			
	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---			
	ジクロロメタン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
基	ベンゼン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
	塩素酸	≦0.6	0.06	---	0.08	---	---	<	---	---	<	---	---	---	0.11			
	クロロ酢酸	≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	<	---			
	クロロホルム	≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	ジクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---			
	ジブロモクロロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	臭素酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---			
	ブロモジクロロメタン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
準	ブロモホルム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---			
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---			
	アルミニウム及びその化合物	≦0.2	0.01	---	0.01	---	---	---	---	---	0.01	---	---	---	0.01			
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	<	---			
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---			
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	5.1	---	---	---	---			
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---			
	塩化物イオン	≦200	1.0	5.1	5.3	5.5	5.3	5.4	5.5	5.5	5.3	5.0	5.5	5.4	5.9			
	カルシウム・マグネシウム等(硬度)	≦300	1	---	29	---	---	30	---	---	30	---	---	---	29			
目	蒸発残留物	≦500	1	---	38	---	---	38	---	---	44	---	---	---	43			
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---			
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---			
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---			
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---			
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---			
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<			
	pH値	5.8～8.6		8.3	8.2	7.9	7.7	7.9	7.6	8.1	7.6	7.6	8.0	8.2	8.1			
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし			
	臭気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし			
残	色度(度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<			
	濁度(度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<			
	残留塩素	≧0.1	0.1	<	0.2	0.3	0.2	0.3	0.3	0.2	0.2	0.3	0.5	0.5	0.5			

上吉山地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

上吉山地区 飲料供給施設																	令和 6年 4月 ～ 令和 7年 3月			
項	目	名	施 設	名 称	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日				
採	水	日	水質基準	下限値	晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴				
天		気																		
水	温	(℃)			12.0	16.0	17.0	22.6	24.6	23.5	23.3	17.5	11.1	4.7	6.5	5.6				
水	一 般 細 菌 (集 落 数 /ml)	≦100	0	0	87	2	32	0	10	2	0	1	0	1	1					
	大 腸 菌	不検出		不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	---	<	---	---	---	---				
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	---	0.001	---	---	0.001	---	---	---	0.002	---	---	0.001	---				
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---				
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	<	---	---	---	<	---	---	<	---				
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---				
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.38	---	---	---	0.37	---	---	0.29	---	---	0.32	---				
	フッ素及びその化合物	≦0.8	0.05	---	0.09	---	---	---	0.09	---	---	0.08	---	---	0.09	---				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	---	<	---	---	---	---				
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	---	<	---	---	---	---				
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---				
	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	---	<	---	---	---	---				
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
質	ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	---				
	塩 素 酸	≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	---	<	---				
	ク ロ ロ 酢 酸	≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	---	<	---				
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---				
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	---	<	---				
	ジ ブ ロ モ ク ロ ロ メ タ ン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---				
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---				
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---				
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	---	<	---				
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---				
基	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---				
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	---	0.013	---	---	<	---				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	---	0.07	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	<	---	---	---	<	---				
	鉄及びその化合物	≦0.3	0.01	---	0.03	---	---	---	0.06	---	---	0.13	---	---	0.04	---				
	銅及びその化合物	≦1.0	0.01	---	<	---	---	<	---	---	<	---	---	---	<	---				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	---	10.4	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	---	<	---	---	<	---	---	<	---	---	---	<	---				
	塩 化 物 イ オ ン	≦200	1.0	7.7	7.4	7.5	7.3	7.6	7.4	7.8	7.2	7.3	7.5	7.5	7.5	7.7				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	70	---	---	---	67	---	---	65	---	---	67	---				
目	蒸 発 残 留 物	≦500	1	---	102	---	---	---	104	---	---	98	---	---	95	---				
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	---	<	---	---	---	---				
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	---	---	---				
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---				
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	---	<	---	---	---	---				
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<	<				
	pH値	5.8～8.6		8.1	8.2	8.2	8.3	8.3	8.3	8.3	8.3	8.3	8.2	8.1	8.2	8.2				
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	色	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	色 度 (度)	≦5	0.5	<	<	0.7	0.8	0.9	0.6	<	2.1	0.6	1.6	<	<	<				
濁 度 (度)	≦2	0.2	<	0.3	<	<	<	<	<	<	<	<	<	<	<	<				
	留 留 塩 酸 素	≧0.1	0.1	0.5	0.4	0.5	<	0.3	0.2	0.2	0.1	0.3	0.3	0.3	0.3	0.1				

下吉山地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名				施 設 名 称		下吉山地区 飲料供給施設											令和 6年 4月 ～ 令和 7年 3月		
採	水	日	水質基準	下限値	4月8日	5月7日	6月3日	7月16日	8月5日	9月2日	10月1日	11月5日	12月2日	1月7日	2月3日	3月10日			
天	気				晴	雨	晴	曇	曇	雨	晴	曇	曇	雨	雨	晴			
水	温	(℃)			14.0	17.0	19.0	22.5	23.2	25.0	22.3	16.5	11.4	6.0	4.0	7.2			
水	一 般 細 菌 (集 落 数 /mL)		≦100	0	2	0	19	7	0	3	2	3	8	1	5	7			
	大 腸 菌	不検出			不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出			
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	---	<	---	---	---	---			
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	---	<	---	---	---	---			
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	ヒ素及びその化合物	≦0.01	0.001	---	---	<	---	---	<	---	---	<	---	---	<	---			
	六価クロム化合物	≦0.02	0.001	---	---	<	---	---	<	---	---	<	---	---	<	---			
	亜硝酸態窒素	≦0.04	0.004	---	---	<	---	---	<	---	---	<	---	---	<	---			
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	---	<	---	---	<	---	---	<	---	---	<	---			
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.93	---	---	---	0.94	---	---	1.16	---	---	0.88	---			
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	---	<	---	---	<	---	---	<	---			
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	---	<	---	---	---	---			
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	---	<	---	---	---	---			
	1,4-ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---			
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	---	<	---	---	---	---			
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
質	ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	塩 素 酸	≦0.6	0.06	---	<	---	---	---	<	---	---	<	---	---	<	---			
	ク ロ ロ 酢 酸	≦0.02	0.002	---	<	---	---	---	<	---	---	<	---	---	<	---			
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	<	---	---	---	<	---	---	<	---	---	<	---			
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	---	<	---	---	<	---	---	<	---			
	ジブロモクロロメタン	≦0.1	0.001	---	<	---	---	---	<	---	---	<	---	---	<	---			
	臭 素 酸	≦0.01	0.001	---	<	---	---	---	<	---	---	<	---	---	<	---			
	総トリハロメタン	≦0.1	0.001	---	<	---	---	---	<	---	---	<	---	---	<	---			
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	---	<	---	---	<	---	---	<	---			
	ブロモジクロロメタン	≦0.03	0.001	---	<	---	---	---	<	---	---	<	---	---	<	---			
基	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	---	<	---	---	<	---	---	<	---			
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	---	<	---	---	<	---	---	<	---			
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	---	<	---	---	---	---			
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	---	0.01	---	---	0.01	---	---	0.02	---			
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	---	<	---	---	<	---	---	0.02	---			
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	---	<	---	---	---	---			
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	---	7.4	---	---	---	---			
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---			
	塩 化 物 イ オ ン	≦200	1.0	8.2	7.7	8.1	7.0	8.1	7.7	7.5	7.0	6.3	8.1	8.6	9.2	---			
	カルシウム・マグネシウム等(硬度)	≦300	1	---	49	---	---	---	50	---	---	48	---	---	40	---	---		
目	蒸 発 残 留 物	≦500	1	---	79	---	---	---	80	---	---	77	---	---	71	---	---		
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	---	<	---	---	---	---	---		
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	0.4	<	<	<	<		
	pH 値	5.8～8.6		7.6	7.7	7.7	7.4	7.5	7.6	7.6	7.6	7.4	7.5	7.6	7.5	7.5	7.5		
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	色 度 (度)	≦5	0.5	<	<	<	0.9	<	<	<	<	<	0.7	<	<	<	<		
濁 度 (度)	≦2	0.2	<	<	<	0.3	<	0.2	<	<	<	0.4	0.3	0.4	0.4	0.4			
	残 留 塩 素	≧0.1	0.1	0.2	0.1	0.5	0.2	0.3	0.1	0.4	0.1	0.1	0.1	0.3	0.1	0.1			

下薬師地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

※ 〇は下検値未満 ―は不検出を表す。単位は記載のない限りmg/Lとする。															
項目	名称	施設名称	下薬師地区 簡易水道												
採水日	水質基準	下限値	4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日	
天気	気温(℃)		雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨	
水質	一般細菌(集落数/ml)	≦100	0	2	0	0	0	0	0	1	2	1	1	0	
	大腸菌	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	<	---	---	---	---	
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	<	---	---	---	---	
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---	
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---	
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---	
	六価クロム化合物	≦0.02	0.001	---	---	---	---	<	---	<	---	---	<	---	
	亜硝酸態窒素	≦0.04	0.004	---	<	---	---	<	---	<	---	---	<	---	
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---	
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.45	---	---	0.40	---	0.72	---	---	0.51	---	
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	<	---	---	<	---	
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	<	---	---	---	---	
	四塩化炭素	≦0.002	0.0002	---	---	---	---	---	---	<	---	---	---	---	
	1,4-ジオキサン	≦0.05	0.005	---	---	---	---	---	---	<	---	---	---	---	
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	<	---	---	---	---	
	基準値	ジクロロメタン	≦0.02	0.001	---	---	---	---	---	---	<	---	---	---	---
		テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---
トリクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---	
ベンゼン		≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---	
塩素酸		≦0.6	0.06	---	<	---	---	<	---	<	---	---	0.10	---	
クロロ酢酸		≦0.02	0.002	---	<	---	---	<	---	<	---	---	<	---	
クロロホルム		≦0.06	0.001	---	<	---	---	<	---	<	---	---	<	---	
ジクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	<	---	---	<	---	
ジブロモクロロメタン		≦0.1	0.001	---	<	---	---	0.001	---	0.002	---	---	<	---	
臭素酸		≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---	
総トリハロメタン		≦0.1	0.001	---	<	---	---	0.002	---	0.003	---	---	<	---	
トリクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	<	---	---	<	---	
ブロモジクロロメタン		≦0.03	0.001	---	<	---	---	0.001	---	0.001	---	---	<	---	
ブロモホルム		≦0.09	0.001	---	<	---	---	<	---	<	---	---	<	---	
ホルムアルデヒド		≦0.08	0.005	---	<	---	---	<	---	<	---	---	<	---	
項目		亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	<	---	---	---	---
		アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	0.01	---	---	0.04	---	0.01	---
		鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	0.02	---	---	<	---
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	<	---	---	---	---	
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	6.1	---	---	---	---	
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	<	---	---	<	---	
	塩化物イオン	≦200	1.0	6.3	6.0	5.9	5.0	6.0	5.9	6.2	5.2	5.1	6.2	7.5	
	カルシウム・マグネシウム等(硬度)	≦300	1	---	45	---	---	41	---	---	37	---	32	---	
	蒸発残留物	≦500	1	---	60	---	---	48	---	---	68	---	53	---	
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	<	---	---	---	---	
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	<	---	---	---	---	
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	<	---	---	---	---	
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	<	---	---	---	---	
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	<	---	---	---	---	
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	0.4	0.3	0.5	<	0.4	0.5	<	<	
	その他	pH値	5.8～8.6	7.4	7.4	7.4	7.2	7.4	7.5	7.5	7.3	7.4	7.3	7.3	<
		臭気	異常でない	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし
		臭度(度)	異常でない	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし
色度(度)		≦5	0.5	<	<	<	1.0	<	0.5	<	1.2	1.5	<	<	
濁度(度)		≦2	0.2	<	<	<	<	<	<	<	0.3	<	<	<	
残留塩素		≧0.1	0.1	0.6	0.3	0.2	0.1	0.2	0.6	0.5	0.3	0.5	0.3	0.4	

上薬師地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名		施 設 名 称		上薬師地区 飲料供給施設												令和 6年 4月 ～ 令和 7年 3月			
採 水 日	水質基準	下限値		4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日				
天 気				雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨				
水 温 (℃)				14.0	18.8	20.1	25.0	28.1	27.9	27.1	19.6	13.1	6.0	6.2	6.4				
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	0	0	0	0	0	0	0	0	0	0	0				
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---				
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	亜 硝 酸 態 窒 素	≦0.04	0.004	<	---	<	---	<	---	---	<	---	---	<	---				
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.22	---	---	0.23	---	---	0.23	---	---	0.24	---				
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	<	<	---	---	<	---				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---				
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---				
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---				
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
ペ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---					
基	塩 素 酸	≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	<	---				
	ク ロ ロ 酢 酸	≦0.02	0.002	---	<	---	---	<	---	<	<	---	---	<	---				
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
	ジ ブ ロ モ ク ロ ロ メ タ ン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
準	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	<	---	---	<	---				
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	<	---				
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	8.9	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	---	<	---	---	<	---	---	<	---	---	<	---				
	塩 化 物 イ オ ン	≦200	1.0	7.1	7.0	7.6	7.1	7.1	7.3	7.3	7.1	6.9	7.1	7.3	7.5				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	74	---	---	76	---	---	76	---	---	77	---				
	蒸 発 残 留 物	≦500	1	---	100	---	---	98	---	---	111	---	---	110	---				
目	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---				
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---				
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<				
	pH 値	5.8～8.6		8.0	8.0	8.0	8.0	7.9	7.9	8.0	8.0	8.0	8.0	8.0	8.0				
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	色 度 (度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<				
濁 度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<					
残 留 塩 素	≧0.1	0.1	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.4	0.3	0.3	0.4	0.4					

大宮・縫原地区 簡易水道

※ “ $<$ ”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項目名			施設名称			大宮・経原地区 簡易水道										令和 6年 4月 ～ 令和 7年 3月			
採水日	水質基準	下限値	4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日					
天気			雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨					
水温（℃）			13.4	17.0	18.0	22.0	23.8	24.7	23.3	18.3	14.4	10.2	9.2	9.4					
水	一般細菌（集落数/mL）	≦100 0	0	0	0	0	0	1	2	0	0	0	0	0					
	大腸菌	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出					
	カドミウム及びその化合物	≦0.003 0.0003	---	---	---	---	---	---	---	<	---	---	---	---					
	水銀及びその化合物	≦0.0005 0.00005	---	---	---	---	---	---	---	<	---	---	---	---					
	セレン及びその化合物	≦0.01 0.001	---	---	---	---	---	---	---	<	---	---	---	---					
	鉛及びその化合物	≦0.01 0.001	---	---	---	---	---	---	---	<	---	---	---	---					
	ヒ素及びその化合物	≦0.01 0.001	---	<	---	---	0.001	---	---	<	---	---	0.001	---					
	六価クロム化合物	≦0.02 0.001	---	<	---	---	<	---	---	<	---	---	<	---					
	亜硝酸態窒素	≦0.04 0.004	---	<	---	---	<	---	---	<	---	---	<	---					
	シアニ化物イオン及び塩化シアニ	≦0.01 0.001	---	<	---	---	<	---	---	---	---	---	<	---					
	硝酸態窒素及び亜硝酸態窒素	≦10 0.10	---	0.33	---	---	0.33	---	---	0.37	---	---	0.38	---					
	フッ素及びその化合物	≦0.8 0.05	---	0.09	---	---	0.09	---	---	0.09	---	---	0.10	---					
	ホウ素及びその化合物	≦1.0 0.1	---	---	---	---	---	---	---	<	---	---	---	---					
	四塩化炭素	≦0.002 0.0002	---	---	---	---	---	---	---	<	---	---	---	---					
	質	1,4-ジオキサン	≦0.05 0.005	---	---	---	---	---	---	---	<	---	---	---	---				
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン		≦0.04 0.004	---	---	---	---	---	---	---	<	---	---	---	---					
ジクロロメタン		≦0.02 0.001	---	---	---	---	---	---	---	<	---	---	---	---					
テトラクロロエチレン		≦0.01 0.001	---	---	---	---	---	---	---	<	---	---	---	---					
トリクロロエチレン		≦0.01 0.001	---	---	---	---	---	---	---	<	---	---	---	---					
ベンゼン		≦0.01 0.001	---	---	---	---	---	---	---	<	---	---	---	---					
塩素		≦0.6 0.06	---	<	---	---	<	---	<	<	---	---	<	---					
クロロ酢酸		≦0.02 0.002	---	<	---	---	<	---	<	<	---	---	<	---					
クロロホルム		≦0.06 0.001	---	<	---	---	<	---	<	<	---	---	<	---					
ジクロロ酢酸		≦0.03 0.002	---	<	---	---	<	---	<	<	---	---	<	---					
基	ジブromotetachlorometan	≦0.1 0.001	---	<	---	---	<	---	<	---	---	<	<	---					
	臭素酸	≦0.01 0.001	---	<	---	---	<	---	<	---	---	<	<	---					
	総トリハロメタン	≦0.1 0.001	---	<	---	---	<	---	<	---	---	<	<	---					
	トリクロロ酢酸	≦0.03 0.002	---	<	---	---	<	---	<	---	---	<	<	---					
	ブロモジクロロメタン	≦0.03 0.001	---	<	---	---	<	---	<	---	---	<	<	---					
	ブロモホルム	≦0.09 0.001	---	<	---	---	<	---	<	---	---	<	<	---					
	ホルムアルデヒド	≦0.08 0.005	---	<	---	---	<	---	<	---	---	<	<	---					
	亜鉛及びその化合物	≦1.0 0.01	---	---	---	---	---	---	<	---	---	---	---	---					
	アルミニウム及びその化合物	≦0.2 0.01	---	<	---	---	<	---	<	---	---	<	<	---					
	項	鉄及びその化合物	≦0.3 0.01	---	<	---	---	<	---	<	---	---	<	<	---				
銅及びその化合物		≦1.0 0.01	---	---	---	---	---	---	<	---	---	---	---	---					
ナトリウム及びその化合物		≦200 1.0	---	---	---	---	---	---	14.4	---	---	---	---	---					
マンガン及びその化合物		≦0.05 0.005	---	---	---	---	---	---	<	---	---	<	<	---					
塩化物イオン		≦200 1.0	9.3	8.9	9.3	8.6	8.6	8.5	8.4	8.2	8.0	9.4	11.3	14.5					
カルシウム・マグネシウム等（硬度）		≦300 1	---	53	---	---	55	---	---	55	---	---	54	---					
懸濁残留物		≦500 1	---	94	---	---	98	---	---	108	---	---	109	---					
陰イオン界面活性剤		≦0.2 0.02	---	---	---	---	---	---	<	---	---	---	---	---					
ジエオスミン		≦0.00001 0.000001	---	---	---	---	---	---	<	---	---	---	---	---					
2-メチルイソボルネオール		≦0.00001 0.000001	---	---	---	---	---	---	<	---	---	---	---	---					
目	非イオン界面活性剤	≦0.02 0.005	---	---	---	---	---	---	---	<	---	---	---	---					
	フェノール類	≦0.005 0.0005	---	---	---	---	---	---	<	---	---	<	<	---					
	有機物等（全有機炭素(TOC)量）	≦3 0.3	<	<	<	<	<	<	<	<	<	<	<	<					
	pH	5.8～8.6 値	7.6	7.6	7.5	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.5	7.5					
	味	異常でない	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし					
	臭	異常でない	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし					
	色度（度）	≦5 0.5	<	<	<	<	<	<	<	<	<	<	<	<					
	濁度（度）	≦2 0.2	<	<	<	<	<	<	<	<	<	<	<	<					
	残留塩素	≧0.1 0.1	0.3	0.3	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.5	0.4					

南宮地地区 飲料供給施設

※ “ $<$ ”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名				施 設 名 称		南宮地地区 飲料供給施設											令和 6年 4月 ～ 令和 7年 3月		
採 水 日	水質基準	下限値		4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日				
天 気				雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨				
水 温 (℃)				10.6	15.5	16.8	19.6	23.5	23.3	22.0	17.0	12.2	7.9	4.0	6.2				
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	0	0	0	1	0	0	0	0	0	0	0				
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---				
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	---	---	---	<	---	---	<	---				
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	---	---	---	<	---	---	<	---	<	<	---				
	シアニ化物イオン及び塩化シアニ	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.11	---	---	0.13	---	---	0.13	---	---	0.12	---				
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---				
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---				
	質	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---			
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン		≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---				
ジ ク ロ ロ メ タ ン		≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
テトラクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
トリクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
ベ ン ゼ ン		≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
塩 素 酸		≦0.6	0.06	---	0.11	---	---	<	---	---	<	---	---	0.06	---				
ク ロ ロ 酢 酸		≦0.02	0.002	---	---	---	---	<	---	---	<	---	---	<	---				
ク ロ ロ ホ ル ム		≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
ジ ク ロ ロ 酢 酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
ジブロモクロロメタン		≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
臭 素 酸		≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
総トリハロメタン		≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
トリクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
基		ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	<	---	---	<	---				
	鉄 及 び そ の 化 合 物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	0.02	---				
	銅 及 び そ の 化 合 物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	10.4	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	塩 化 物 イ オ ン	≦200	1.0	8.4	8.2	8.5	8.4	8.4	8.4	8.2	8.3	8.2	8.3	8.5	8.7				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	77	---	---	86	---	---	84	---	---	82	---				
	無 発 残 留 物	≦500	1	---	120	---	---	129	---	---	134	---	---	132	---				
	陰 イ オ ン 界 面 活 性 剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---				
	ジ エ オ ス ミ ン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
目	非 イ オ ン 界 面 活 性 剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	フェ ノ ール 類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---				
	有 機 物 等 (全 有 機 炭 素 (TOC) 量)	≦3	0.3	---	<	---	<	<	<	<	<	<	<	<	<				
	pH	5.8～8.6		7.5	7.5	7.5	7.4	7.5	7.3	7.4	7.4	7.4	7.4	7.4	7.4				
	味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	色 度 (度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<				
	濁 度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<				
	残 留 塩 素	≧1	0.1	0.3	0.4	0.3	0.2	0.3	0.2	0.2	0.4	0.5	0.4	0.4	0.3				

東俣地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項	目	名	施 設 名 称	東俣地区 飲料供給施設											令和 6年 4月 ～ 令和 7年 3月		
				4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日		
採	水	日	水質基準	下限値													
天	気			雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨		
水	温	(℃)		13.3	18.3	19.2	23.1	29.5	26.1	24.8	16.6	10.3	5.0	3.5	6.2		
水	一 般 細 菌 (集 落 数 /ml)	≦100	0	0	0	0	0	0	0	0	0	0	0	0	0		
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出		
	カドミウム及びその化合物	≦0.003	0.0003	—	—	—	—	—	—	—	<	—	—	—	—		
	水銀及びその化合物	≦0.0005	0.00005	—	—	—	—	—	—	—	<	—	—	—	—		
	セレン及びその化合物	≦0.01	0.001	—	—	—	—	—	—	—	<	—	—	—	—		
	鉛及びその化合物	≦0.01	0.001	—	—	—	—	—	—	—	<	—	—	—	—		
	ヒ素及びその化合物	≦0.01	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
	六価クロム化合物	≦0.02	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
	亜硝酸態窒素	≦0.04	0.004	—	<	—	—	<	—	—	<	—	—	<	—		
	シアン化物イオン及び塩化シアン	≦0.01	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	—	0.10	—	—	0.10	—	—	0.10	—	—	—	0.12		
	フッ素及びその化合物	≦0.8	0.05	—	0.07	—	—	0.07	—	—	0.07	—	—	—	0.08		
	ホウ素及びその化合物	≦1.0	0.1	—	—	—	—	—	—	—	<	—	—	—	—		
	四 塩 化 炭 素	≦0.002	0.0002	—	—	—	—	—	—	—	<	—	—	—	—		
	1,4- ジ オ キ サ ン	≦0.05	0.005	—	—	—	—	—	—	—	<	—	—	—	—		
	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	—	—	—	—	—	—	—	<	—	—	—	—		
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	—	—	—	—	—	—	—	<	—	—	—	—		
	テトラクロロエチレン	≦0.01	0.001	—	—	—	—	—	—	—	<	—	—	—	—		
	トリクロロエチレン	≦0.01	0.001	—	—	—	—	—	—	—	<	—	—	—	—		
基	ベ ン ゼ ン	≦0.01	0.001	—	—	—	—	—	—	—	<	—	—	—	—		
	塩 素 酸	≦0.6	0.06	—	<	—	—	<	—	—	<	—	—	—	0.07		
	ク ロ ロ 酢 酸	≦0.02	0.002	—	<	—	—	<	—	—	<	—	—	<	—		
	ク ロ ロ ホ ル ム	≦0.06	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	—	<	—	—	<	—	—	<	—	—	<	—		
	ジ ブ ロ モ ク ロ ロ メ タ ン	≦0.1	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
	臭 素 酸	≦0.01	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
	総トリハロメタン	≦0.1	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
	トリクロロ酢酸	≦0.03	0.002	—	<	—	—	<	—	—	<	—	—	<	—		
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
準	ブ ロ モ ホ ル ム	≦0.09	0.001	—	<	—	—	<	—	—	<	—	—	<	—		
	ホルムアルデヒド	≦0.08	0.005	—	<	—	—	<	—	—	<	—	—	<	—		
	亜鉛及びその化合物	≦1.0	0.01	—	—	—	—	—	—	—	0.02	—	—	—	—		
	アルミニウム及びその化合物	≦0.2	0.01	—	<	—	—	<	—	—	<	—	—	<	—		
	鉄及びその化合物	≦0.3	0.01	—	0.10	—	—	0.08	—	—	0.10	—	—	0.06	—		
	銅及びその化合物	≦1.0	0.01	—	—	—	—	—	—	—	<	—	—	—	—		
	ナトリウム及びその化合物	≦200	1.0	—	—	—	—	—	—	—	7.1	—	—	—	—		
	マンガン及びその化合物	≦0.05	0.005	—	—	—	—	—	—	—	<	—	—	—	—		
	塩 化 物 イ オ ン	≦200	1.0	5.9	5.6	5.9	5.7	5.9	5.7	5.7	5.7	5.7	5.9	6.2	6.1		
	カルシウム・マグネシウム等(硬度)	≦300	1	—	35	—	—	36	—	—	35	—	—	36	—		
目	蒸 発 残 留 物	≦500	1	—	58	—	—	60	—	—	70	—	—	74	—		
	陰イオン界面活性剤	≦0.2	0.02	—	—	—	—	—	—	—	<	—	—	—	—		
	ジエオスミン	≦0.00001	0.000001	—	—	—	—	—	—	—	<	—	—	—	—		
	2-メチルイソボルネオール	≦0.00001	0.000001	—	—	—	—	—	—	—	<	—	—	—	—		
	非イオン界面活性剤	≦0.02	0.005	—	—	—	—	—	—	—	<	—	—	—	—		
	フェノール類	≦0.005	0.0005	—	—	—	—	—	—	—	<	—	—	—	—		
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<		
	pH 値	5.8～8.6		7.0	7.0	6.9	7.0	7.0	6.9	6.9	7.0	6.9	6.9	6.8	6.8		
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	色 度 (度)	≦5	0.5	3.3	1.0	6.6	1.3	1.1	0.7	<	1.1	<	<	<	<		
	濁 度 (度)	≦2	0.2	1.4	<	2.8	<	<	<	<	<	<	<	<	<		
残	留	塩 素	≧0.1	0.1	0.3	0.1	0.2	0.1	0.1	0.1	0.1	0.3	0.5	0.3	0.5		

南西俣地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名		施 設 名 称		南西俣地区 簡易水道												令和 6年 4月 〜 令和 7年 3月	
採 水 日		水質基準	下限値	4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日		
天 気				雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨		
水 温 (℃)				12.5	17.6	19.5	23.7	27.1	25.7	26.1	19.7	13.5	7.0	6.5	7.0		
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	8	0	1	0	0	0	0	0	0	0	0	0		
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出		
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---		
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---		
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	<	---	---	<	---	---	<	---		
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.54	---	---	0.57	---	---	0.53	---	---	0.52	---		
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---		
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---		
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---		
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	質	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---	
		ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---	
		テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	
		トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	
ベ ン ゼ ン		≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
塩 素 酸		≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	<	---		
ク ロ ロ 酢 酸		≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
ク ロ ロ ホ ル ム		≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
ジ ク ロ ロ 酢 酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
ジ ブ ロ モ ク ロ ロ メ タ ン		≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
基	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---		
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---		
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	<	---	---	<	---		
	鉄 及 び そ の 化 合 物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	<	---		
	銅 及 び そ の 化 合 物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---		
項	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	7.3	---	---	---	---		
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	塩 化 物 イ オ ン	≦200	1.0	6.0	5.9	6.1	6.0	6.0	6.1	5.9	5.8	5.7	6.0	6.3	6.4		
	カルシウム・マグネシウム等(硬度)	≦300	1	---	48	---	---	49	---	---	48	---	---	46	---		
	蒸 発 残 留 物	≦500	1	---	78	---	---	73	---	---	84	---	---	81	---		
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---		
	ジ ェ オ ス ミ ン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---		
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---		
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	フ ェ ノ ー ル 類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---		
目	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<		
	pH 値	5.8～8.6		7.5	7.6	7.5	7.3	7.4	7.3	7.3	7.4	7.3	7.4	7.5	7.5		
	味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	色 度 (度)	≦5	0.5	0.6	<	<	<	<	<	<	<	<	<	<	<		
	濁 度 (度)	≦2	0.2	0.5	<	<	<	<	<	<	<	<	<	<	<		
	残 留 塩 素	≧0.1	0.1	0.2	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.2	0.3	0.3	0.3		

間戸地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項目名		施設名称		間戸地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月			
採水日	水質基準	下限値		4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日				
天気	気			雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨				
水温 (℃)				13.0	17.2	19.0	23.0	27.2	25.5	23.9	17.1	9.7	4.5	5.5	6.2				
水	一般細菌 (集落数 /mL)	≦100	0	0	0	1	0	0	0	0	0	0	0	5	0				
	大腸菌	不検出		不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---				
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	六価クロム化合物	≦0.02	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	亜硝酸態窒素	≦0.04	0.004	<	---	---	---	<	---	---	<	---	---	<	---				
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.87	---	---	0.86	---	---	0.99	---	---	0.90	---				
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---				
	四塩化炭素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---				
	1,4-ジオキサン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---				
	ジクロロメタン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
質	ベンゼン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	塩素酸	≦0.6	0.06	---	0.08	---	---	<	---	---	<	---	---	0.07	---				
	クロロ酢酸	≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
	クロロホルム	≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	ジクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
	ジブロモクロロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	臭素酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---				
	ブロモジクロロメタン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
基	ブロモホルム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	0.01	---	---	0.01	---	---	0.04	---	---	0.03	---				
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	0.01	---	---	0.01	---				
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	6.2	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	---	<	---	---	<	---	---	<	---	---	<	---				
	塩化物イオン	≦200	1.0	6.0	5.8	6.0	5.1	5.9	5.9	5.9	5.5	4.9	6.1	6.3	6.9				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	54	---	---	56	---	---	51	---	---	49	---				
目	蒸発残留物	≦500	1	---	70	---	---	70	---	---	72	---	---	82	---				
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---				
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---				
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<				
	pH値	5.8～8.6		7.9	7.9	7.8	7.3	7.5	7.4	7.6	7.6	7.5	7.5	7.8	7.7				
	臭気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	色度 (度)	≦5	0.5	<	<	<	0.8	<	<	<	0.5	0.8	0.7	<	<				
濁度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<					
残留塩素	≧0.1	0.1	0.3	0.2	0.2	0.3	0.3	0.2	0.3	0.4	0.4	0.2	0.3	0.4					

上宇坂第1地区 簡易水道

※ “ $<$ ”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項目名			施設名称		上宇坂第1地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月			
採	水	日	水質基準	下限値	4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日				
天	気				雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨				
水温 (℃)					13.2	18.1	18.6	23.6	27.4	24.6	23.8	17.7	11.8	6.5	6.2	7.3				
水	一般細菌 (集落数 /mL)	≦100	0	0	0	0	0	1	2	2	0	5	0	3	0	0				
	大腸菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	---	<	---	---	---	---				
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---				
	六価クロム化合物	≦0.02	0.001	---	0.001	---	---	0.001	---	---	0.001	---	---	---	0.001	---				
	亜硝酸態窒素	≦0.04	0.004	<	---	---	---	<	---	---	<	<	---	---	<	<				
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	<	---	---	<	<				
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.54	---	---	0.56	---	---	0.61	---	---	---	0.61	---				
	フッ素及びその化合物	≦0.8	0.05	---	---	---	---	<	---	---	<	---	---	---	<	<				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---	---				
	四塩化炭素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---	---				
	質	1,4-ジオキサン	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---			
シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン		≦0.04	0.004	---	---	---	---	---	---	---	---	<	---	---	---	---				
ジクロロメタン		≦0.02	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
テトラクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
トリクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
ベンゼン		≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---				
塩素		≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	---	<	<				
クロロ酢酸		≦0.02	0.002	<	---	---	---	<	---	---	<	<	---	---	<	<				
クロロホルム		≦0.06	0.001	---	<	---	---	---	---	---	<	---	---	---	<	<				
ジクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	---	<	<	---	---	<	<				
ジブロモクロロメタン		≦0.1	0.001	---	---	---	---	<	---	---	0.002	---	---	---	<	<				
臭素酸		≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	---	<	<				
総トリハロメタン		≦0.1	0.001	---	<	---	---	<	---	---	0.002	---	---	---	<	<				
トリクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	---	<	<				
準		ブロモジクロロメタン	≦0.03	0.001	---	<	---	---	<	---	---	<	<	---	---	<	<			
	ブロモホルム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	---	<	<				
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	---	<	<				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	<	---	---	0.03	---	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	0.01	---	---	---	0.02	---	---	0.06	---	---	0.03	---				
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	0.02	---	---	---	<	<				
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	<	<				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	4.9	---	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	<	---	---	---	<	---	---	<	<	---	---	<	<				
	塩化物イオン	≦200	1.0	6.0	5.9	5.9	5.5	5.9	6.0	6.2	5.6	5.4	6.1	6.4	7.0	7.0				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	39	---	---	---	39	---	---	36	---	---	37	---				
	濁度残留物	≦500	1	---	52	---	---	---	54	---	---	54	---	---	64	---				
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---	---				
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---	---				
項	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---	---				
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---	---				
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<	<				
	pH値	5.8～8.6		8.1	8.2	8.1	7.9	7.9	8.0	8.0	7.9	7.9	7.9	7.9	7.9	7.9				
	味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	色度 (度)	≦5	0.5	<	<	<	0.8	<	0.6	<	1.1	0.8	0.6	<	<	<				
	濁度 (度)	≦2	0.2	<	<	<	0.2	<	<	<	0.3	<	<	<	<	<				
	目	残留塩素	≧0.1	0.1	0.5	0.4	0.4	0.2	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.2	0.2			

上宇坂第2地区 簡易水道

※ “<”は下限値未満 “―”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名		施 設 名 称		上宇坂第2地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月			
採 水 日	水質基準	下限値		4月9日	5月8日	6月4日	7月17日	8月6日	9月3日	10月2日	11月6日	12月3日	1月8日	2月4日	3月11日				
天 気	気			雨	雨	晴	雨	晴	曇	晴	晴	晴	雪	雪	雨				
水 温 (℃)				13.0	17.7	19.0	22.3	26.3	27.3	27.0	20.8	16.0	10.6	9.5	9.0				
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	1	0	0	0	6	0	1	0	0	0	0				
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---				
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	---	---	---	<	---	---	<	---	---	<	---				
	亜 硝 酸 態 窒 素	≦0.04	0.004	<	---	<	---	<	---	---	<	---	---	<	---				
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.63	---	---	0.71	---	---	0.86	---	---	0.62	---				
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---				
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---				
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---				
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---				
質	ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---	---				
	塩 素 酸	≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	0.07	---				
	ク ロ ロ 酢 酸	≦0.02	0.002	<	---	---	---	<	---	---	<	---	---	<	---				
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	<	---	---	0.001	---	---	0.002	---	---	<	---				
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	<	---	<	<	---	---	<	---				
	ジ ブ ロ モ ク ロ ロ メ タ ン	≦0.1	0.001	---	0.002	---	---	0.003	---	---	0.005	---	---	0.002	---				
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---				
	総トリハロメタン	≦0.1	0.001	---	0.004	---	---	0.007	---	---	0.010	---	---	0.003	---				
	トリクロロ酢酸	≦0.03	0.002	<	<	---	---	<	---	<	<	---	---	<	---				
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	0.001	---	---	0.002	---	---	0.003	---	---	0.001	---				
基	ブ ロ モ ホ ル ム	≦0.09	0.001	---	0.001	---	---	0.001	---	---	<	---	---	<	---				
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	0.02	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	<	---	---	<	---				
	鉄 及 び そ の 化 合 物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	<	---				
	銅 及 び そ の 化 合 物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	6.5	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	<	---	---	---	<	---	<	<	---	---	<	---				
	塩 化 物 イ オ ン	≦200	1.0	6.6	6.4	6.2	5.7	6.5	6.2	6.6	5.4	5.5	6.4	6.8	7.5				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	51	---	---	48	---	---	38	---	---	44	---				
目	蒸 発 残 留 物	≦500	1	---	69	---	---	70	---	---	62	---	---	74	---				
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---				
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---				
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---				
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---				
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	0.3	<	<	0.3	<	<	<				
	pH 値	5.8～8.6		7.7	7.8	7.5	7.4	7.5	7.5	7.6	7.2	7.5	7.6	7.8	7.7				
	臭 味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
	色 度 (度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<				
濁 度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<					
残 留 塩 素	≧0.1	0.1	0.4	0.4	0.3	0.2	0.3	0.1	0.3	0.3	0.4	0.5	0.5	0.6					

西市布地区 飲料供給施設

※ “<”は下限値未満 “―”は未検査を表す。 単位は記載のない限り“mg/L”とする。

項 目 名			施 設 名 称		西市布地区 飲料供給施設											令和 6年 4月 ～ 令和 7年 3月	
採 水 日			水質基準	下限値	4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日	
天 気					晴	曇	晴	晴	晴	晴	雨	曇	曇	雪	雨	曇	
水 温 (℃)					14.0	17.5	21.0	23.0	25.5	25.5	26.2	20.5	15.0	6.7	4.5	5.8	
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	2	0	0	0	0	1	0	0	0	0	0	0	
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	---	<	---	---	---	---	
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	---	<	---	---	---	---	
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---	
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---	
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---	
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---	
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	<	---	---	---	<	---	---	<	---	
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---	
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.47	---	---	0.59	---	---	---	0.80	---	---	0.38	---	
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	---	<	---	---	<	---	
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	---	<	---	---	---	---	
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	---	<	---	---	---	---	
	1,4-ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---	
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	---	<	---	---	---	---	
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---	
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---	
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---	
ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---		
基	塩 素 酸	≦0.6	0.06	---	0.12	---	---	0.08	---	---	---	<	---	---	0.13	---	
	ク ロ ロ 酢 酸	≦0.02	0.002	---	<	---	---	<	---	---	---	<	---	---	<	---	
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	0.005	---	---	0.003	---	---	---	0.004	---	---	<	---	
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	<	---	---	<	<	---	---	<	---	
	ジ ブ ロ モ ク ロ ロ メ タ ン	≦0.1	0.001	---	<	---	---	<	---	---	---	0.002	---	---	0.002	---	
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---	
	総トリハロメタン	≦0.1	0.001	---	0.008	---	---	0.005	---	---	---	0.010	---	---	0.004	---	
	トリクロロ酢酸	≦0.03	0.002	---	0.002	---	---	0.003	---	---	---	0.003	<	---	<	---	
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	0.003	---	---	0.002	---	---	---	0.004	---	---	0.002	---	
	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---	
項	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	---	<	---	---	<	---	
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	---	<	---	---	---	---	
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	0.01	---	---	---	0.02	---	---	0.01	---	
	鉄 及 び そ の 化 合 物	≦0.3	0.01	---	<	---	---	<	---	---	---	<	---	---	0.01	---	
	銅 及 び そ の 化 合 物	≦1.0	0.01	---	---	---	---	---	---	---	---	<	---	---	---	---	
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	---	5.6	---	---	---	---	
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---	
	塩 化 物 イ オ ン	≦200	1.0	6.1	5.9	5.6	4.4	5.2	5.1	5.6	4.4	5.2	6.8	9.5	8.5	---	
	カルシウム・マグネシウム等(硬度)	≦300	1	---	33	---	---	38	---	---	---	30	---	---	28	---	
	蒸 発 残 留 物	≦500	1	---	41	---	---	50	---	---	---	50	---	---	54	---	
目	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	---	<	---	---	---	---	
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	---	---	---	
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	---	---	---	
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---	
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	---	<	---	---	---	---	
	有機物等(全有機炭素(TOC)量)	≦3	0.3	0.4	0.3	0.4	0.7	0.4	0.7	0.3	0.6	0.8	0.5	0.4	0.4	---	
	pH 値	5.8～8.6		7.5	7.5	7.3	7.4	7.7	7.3	7.3	7.3	7.6	7.5	7.3	7.4	7.3	
	味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	
	色 度 (度)	≦5	0.5	0.5	<	0.7	1.5	0.6	1.3	<	0.9	2.1	1.2	<	<	<	
濁 度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<	<		
残 留 塩 素			≧0.1	0.1	0.1	0.2	0.1	0.2	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.3	

上味見地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項	目	名	施 設	名 称	上味見地区 簡易水道												令和 6年 4月 〜 令和 7年 3月		
採 水	天 気	水 温 (℃)	水質基準	下限値	4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日			
					晴	曇	晴	晴	晴	雨	曇	雨	曇	雪	雨	曇			
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	0	0	0	0	0	0	0	0	0	0	6.2	6.6			
	大 腸 菌	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出			
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	---	<	---	---	---	---			
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	---	<	---	---	---	---			
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	---	<	---	---	---	---			
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	<	---	---	---	<	---	---	<	---			
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	---	<	---			
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.10	---	0.10	---	---	---	0.11	---	---	---	0.35	---			
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	---	<	---			
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---	---			
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---	---			
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---	---			
	質	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---	---		
		ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---	---		
		テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	---		
		トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	---		
ベ ン ゼ ン		≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	---			
塩 素 酸		≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	---	<	---			
ク ロ ロ 酢 酸		≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	---	<	---			
ク ロ ロ ホ ル ム		≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---			
ジ ク ロ ロ 酢 酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	---	<	---			
ジ ブ ロ モ ク ロ ロ メ タ ン		≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---			
基	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---			
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---			
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	---	<	---			
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---			
	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	---	<	---			
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	---	<	---			
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	<	---	---	<	---	---	---	---	---			
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	<	---	---	---	<	---			
	鉄 及 び そ の 化 合 物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	---	<	---			
	銅 及 び そ の 化 合 物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---	---			
目	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	---	7.8	---	---	---	---			
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---			
	塩 化 物 イ オ ン	≦200	1.0	6.0	5.9	6.1	6.1	6.1	6.3	6.1	5.8	5.9	6.1	5.9	6.2	6.2			
	カルシウム・マグネシウム等(硬度)	≦300	1	---	56	---	---	---	57	---	---	56	---	---	54	---			
	蒸 発 残 留 物	≦500	1	---	86	---	---	---	92	---	---	92	---	---	88	---			
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---	---			
	ジ ェ オ ス ミ ン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---	---			
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---	---			
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---	---			
	フ ェ ノ ー ル 類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---	---			
有 機 物 等 (全 有 機 炭 素 (TOC) 量)	pH 値	5.8〜8.6	---	7.3	7.3	7.3	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.7	7.7			
	味	異常でない	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし			
	臭 気	異常でない	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし			
	色 度 (度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<	<			
	濁 度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<	<			
残 留 塩 素	≧0.1	0.1	0.4	0.4	0.4	0.3	0.5	0.5	0.2	0.3	0.4	0.3	0.4	0.4	0.5				

神当部地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項目名		施設名称		神当部地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月		
採	水 日	水質基準	下限値	4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日			
天	気			晴	曇	晴	晴	晴	晴	雨	曇	曇	雪	雨	曇			
水	温 (℃)			11.5	16.5	20.0	22.0	23.2	24.5	22.2	15.5	12.0	6.5	4.6	5.3			
水	一般細菌(集落数 /mL)	≦100	0	0	0	0	0	0	192	0	0	0	0	0	0			
	大腸菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出			
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---			
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---			
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	六価クロム化合物	≦0.02	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	亜硝酸態窒素	≦0.04	0.004	<	---	---	---	<	---	---	<	---	---	<	---			
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.23	---	---	0.23	---	---	0.26	---	---	0.24	---			
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---			
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---			
	四塩化炭素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---			
	1,4-ジオキサン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---			
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---			
	質	ジクロロメタン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
テトラクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
トリクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
ベンゼン		≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---			
塩素酸		≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	<	---			
クロロ酢酸		≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	<	---			
クロロホルム		≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
ジクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---			
ジブロモクロロメタン		≦0.1	0.001	---	0.001	---	---	<	---	---	---	---	---	<	---			
臭素酸		≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
総トリハロメタン		≦0.1	0.001	---	0.001	---	---	<	---	---	<	---	---	<	---			
トリクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---			
ブロモジクロロメタン		≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
ブロモホルム		≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---			
ホルムアルデヒド		≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---			
基		亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---		
		アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	<	---	---	<	---		
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	<	---			
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	<	---	---	---	---			
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	7.2	---	---	---	---			
	マンガン及びその化合物	≦0.05	0.005	---	<	---	---	<	---	---	<	---	---	<	---			
	塩化物イオン	≦200	1.0	5.6	5.5	5.7	5.6	5.5	5.8	5.6	5.4	5.3	5.7	5.7	6.0			
	カルシウム・マグネシウム等(硬度)	≦300	1	---	57	---	---	60	---	---	58	---	---	59	---			
	蒸発残留物	≦500	1	---	86	---	---	85	---	---	88	---	---	88	---			
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---			
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---			
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---			
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---			
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---			
	項	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<		
		pH値	5.8～8.6		7.7	7.7	7.7	7.4	7.4	7.4	7.6	7.7	7.4	7.4	7.6	7.5		
		臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
色度(度)		≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<			
濁度(度)		≦2	0.2	<	<	<	<	<	0.3	<	<	<	<	<	<			
目		残留塩素	≧0.1	0.1	0.3	0.3	0.2	0.4	0.2	0.4	0.4	0.4	0.3	0.4	0.3	0.4		

味見河内地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項	目	名	施 設	名 称	味見河内地区 簡易水道												令和 6年 4月 ～ 令和 7年 3月		
					4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日			
採	水	日	水質基準	下限値															
天	気				晴	曇	晴	晴	晴	晴	雨	曇	曇	雪	雨	曇			
水	温	(℃)			12.0	15.6	20.5	23.0	23.1	23.5	21.2	17.0	11.0	5.3	6.0	6.6			
水	一 般 細 菌 (集落数 /ml)	≦100	0		0	0	0	0	0	0	0	0	0	0	0	0			
	大 腸 菌	不検出			不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出			
	カドミウム及びその化合物	≦0.003	0.0003		---	---	---	---	---	---	---	<	---	---	---	---			
	水銀及びその化合物	≦0.0005	0.00005		---	---	---	---	---	---	---	<	---	---	---	---			
	セレン及びその化合物	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---			
	鉛及びその化合物	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---			
	ヒ素及びその化合物	≦0.01	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
	六価クロム化合物	≦0.02	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
	亜硝酸態窒素	≦0.04	0.004		---	<	---	---	<	---	---	<	---	---	<	---			
	シアン化物イオン及び塩化シアン	≦0.01	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10		---	0.55	---	---	0.53	---	---	0.53	---	---	---	0.51			
	フッ素及びその化合物	≦0.8	0.05		---	<	---	---	<	---	---	<	---	---	<	---			
	ホウ素及びその化合物	≦1.0	0.1		---	---	---	---	---	---	---	<	---	---	---	---			
	四塩化炭素	≦0.002	0.0002		---	---	---	---	---	---	---	<	---	---	---	---			
	1,4-ジオキサン	≦0.05	0.005		---	---	---	---	---	---	---	<	---	---	---	---			
	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004		---	---	---	---	---	---	---	<	---	---	---	---			
	ジクロロメタン	≦0.02	0.001		---	---	---	---	---	---	---	<	---	---	---	---			
	テトラクロロエチレン	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---			
	トリクロロエチレン	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---			
質	ベンゼン	≦0.01	0.001		---	---	---	---	---	---	---	<	---	---	---	---			
	塩素酸	≦0.6	0.06		---	<	---	---	<	---	---	<	---	---	---	<			
	クロロ酢酸	≦0.02	0.002		---	<	---	---	<	---	---	<	---	---	<	---			
	クロロホルム	≦0.06	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
	ジクロロ酢酸	≦0.03	0.002		---	<	---	---	<	---	---	<	---	---	<	---			
	ジブロモクロロメタン	≦0.1	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
	臭素酸	≦0.01	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
	総トリハロメタン	≦0.1	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
	トリクロロ酢酸	≦0.03	0.002		---	<	---	---	<	---	---	<	---	---	<	---			
	ブロモジクロロメタン	≦0.03	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
基	ブロモホルム	≦0.09	0.001		---	<	---	---	<	---	---	<	---	---	<	---			
	ホルムアルデヒド	≦0.08	0.005		---	<	---	---	<	---	---	<	---	---	<	---			
	亜鉛及びその化合物	≦1.0	0.01		---	---	---	---	---	---	---	0.11	---	---	---	---			
	アルミニウム及びその化合物	≦0.2	0.01		---	0.02	---	---	0.04	---	---	0.02	---	---	---	0.02			
	鉄及びその化合物	≦0.3	0.01		---	0.09	---	---	0.42	---	---	0.05	---	---	---	0.03			
	銅及びその化合物	≦1.0	0.01		---	---	---	---	---	---	---	<	---	---	---	---			
	ナトリウム及びその化合物	≦200	1.0		---	---	---	---	---	---	---	6.1	---	---	---	---			
	マンガン及びその化合物	≦0.05	0.005		---	---	---	---	---	---	---	<	---	---	---	---			
	塩化物イオン	≦200	1.0		5.6	5.6	5.8	5.4	5.7	5.6	5.6	5.2	5.1	5.7	5.6	6.2			
	カルシウム・マグネシウム等(硬度)	≦300	1		---	32	---	---	34	---	---	33	---	---	32	---			
目	蒸発残留物	≦500	1		---	54	---	---	60	---	---	69	---	---	48	---			
	陰イオン界面活性剤	≦0.2	0.02		---	---	---	---	---	---	---	<	---	---	---	---			
	ジェオスミン	≦0.00001	0.000001		---	---	---	---	---	---	---	<	---	---	---	---			
	2-メチルイソボルネオール	≦0.00001	0.000001		---	---	---	---	---	---	---	<	---	---	---	---			
	非イオン界面活性剤	≦0.02	0.005		---	---	---	---	---	---	---	<	---	---	---	---			
	フェノール類	≦0.005	0.0005		---	---	---	---	---	---	---	<	---	---	---	---			
	有機物等(全有機炭素(TOC)量)	≦3	0.3		<	<	<	<	<	<	<	<	<	<	<	<			
	pH値	5.8～8.6			7.8	8.0	7.9	7.5	7.6	7.5	7.5	7.6	7.6	7.7	7.8	7.7			
	味	異常でない			異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし			
	臭気	異常でない			異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし			
色	色度(度)	≦5	0.5		0.7	1.0	<	4.2	4.0	<	<	0.7	<	1.0	<	1.0			
	濁度(度)	≦2	0.2		<	<	<	0.2	1.5	<	<	<	<	0.3	<	0.5			
	残留塩素	≧0.1	0.1		0.2	0.2	0.4	0.3	0.2	0.2	0.3	0.1	0.3	0.4	0.4	0.3			

下味見地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項目名		施設名称		下味見地区 簡易水道										令和 6年 4月 ～ 令和 7年 3月			
採水日	水質基準	下限値		4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日		
天気	気			晴	曇	晴	晴	晴	晴	雨	曇	曇	雪	雨	曇		
水温 (℃)				11.0	17.0	19.5	23.4	27.0	26.0	24.0	16.5	12.5	5.6	4.8	6.6		
水	一般細菌 (集落数 /ml)	≦100	0	0	0	0	0	1	0	0	0	0	0	0	0		
	大腸菌	不検出		不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出		
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---		
	水銀及びその化合物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---		
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	ヒ素及びその化合物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	六価クロム化合物	≦0.02	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	亜硝酸態窒素	≦0.04	0.004	---	<	---	---	<	---	---	<	---	---	<	---		
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.59	---	---	0.52	---	---	0.69	---	---	0.60	---		
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	<	<	---	---	<	---		
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---		
	四塩化炭素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---		
	1,4-ジオキサン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---		
	ジクロロメタン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---		
質	ベンゼン	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---	---		
	塩素酸	≦0.6	0.06	---	<	---	---	<	---	<	---	---	---	0.09	---		
	クロロ酢酸	≦0.02	0.002	---	<	---	---	<	---	<	---	---	<	<	---		
	クロロホルム	≦0.06	0.001	---	<	---	---	<	---	<	---	---	---	<	---		
	ジクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	ジブロモクロロメタン	≦0.1	0.001	---	<	---	---	0.001	---	---	0.001	---	---	0.001	---		
	臭素酸	≦0.01	0.001	---	<	---	---	<	---	<	---	---	---	<	---		
	総トリハロメタン	≦0.1	0.001	---	<	---	---	0.001	---	---	0.001	---	---	0.001	---		
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---		
	ブロモジクロロメタン	≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
基	ブロモホルム	≦0.09	0.001	---	<	---	---	<	---	---	<	---	---	<	---		
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---		
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	0.16	---	---	---	---		
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	0.01	---	---	<	---		
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	<	---		
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	0.02	---	---	---	---		
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	5.6	---	---	---	---		
	マンガン及びその化合物	≦0.05	0.005	---	<	---	---	<	---	<	<	---	---	<	---		
	塩化物イオン	≦200	1.0	6.8	5.3	6.8	6.0	6.6	6.4	6.9	6.2	6.2	7.3	8.3	9.0		
	カルシウム・マグネシウム等(硬度)	≦300	1	---	31	---	---	52	---	---	47	---	---	43	---		
目	蒸発残留物	≦500	1	---	40	---	---	70	---	---	74	---	---	58	---		
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---		
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---		
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---		
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---		
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---		
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	0.3	<	<	<	<	<	<	<	<		
	pH値	5.8～8.6		7.4	6.5	7.3	7.1	7.2	7.1	7.2	7.1	7.1	7.2	7.2	7.2		
	臭	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
	臭気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし		
残	色度 (度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<		
	濁度 (度)	≦2	0.2	<	<	<	<	<	<	<	<	<	<	<	<		
	残留塩素	≧0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.3	0.3	0.4	0.4		

横越地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名 称			横越地区 飲料供給施設													令和 6年 4月 〜 令和 7年 3月		
採 水 日	水質基準	下限値	4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日				
天 気			晴	曇	晴	晴	晴	晴	雨	曇	曇	雪	雨	曇				
水 温 (℃)			10.0	12.7	15.2	22.0	23.7	23.5	21.8	18.0	13.5	6.3	5.2	4.5				
水 質	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	2	4	125	137	3	6	3	0	0	2				
	大 腸 菌	不検出	不検出	不検出	不検出	不検出	検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	<	---	---	---	---				
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---				
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	0.002	---	---	<	---	<	---	---	<	---				
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	<	---	<	---	---	<	---				
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---				
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.32	---	0.85	---	---	0.64	---	---	1.04	---				
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	<	---	---	<	---				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	<	---	---	---	---				
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	<	---	---	---	---				
	1,4-ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	<	---	---	---	---				
	トランス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	<	---	---	---	---				
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	<	---	---	---	---				
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
基 準	ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
	塩 素 酸	≦0.6	0.06	---	<	---	---	<	---	<	---	---	0.12	---				
	ク ロ ロ 酢 酸	≦0.02	0.002	---	<	---	---	<	---	<	---	---	<	---				
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	<	---	---	<	---	<	---	---	<	---				
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	<	---	<	---	---	<	---				
	ジ ブ ロ モ ク ロ ロ メ タ ン	≦0.1	0.001	---	<	---	---	<	---	<	---	---	<	---				
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---				
	総トリハロメタン	≦0.1	0.001	---	<	---	---	<	---	<	---	---	<	---				
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	<	---	---	<	---				
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	---	<	---	---	<	---	<	---	---	<	---				
項 目	ブ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	<	---	<	---	---	<	---				
	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	<	---	---	<	---				
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	<	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	0.01	---	---	<	---	<	---	---	<	---				
	鉄 及 び そ の 化 合 物	≦0.3	0.01	---	<	---	---	0.02	---	<	---	---	<	---				
	銅 及 び そ の 化 合 物	≦1.0	0.01	---	---	---	---	---	---	0.01	---	---	---	---				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	7.1	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	<	---	---	---	---				
	塩 化 物 イ オ ン	≦200	1.0	6.1	6.2	5.2	4.7	4.6	5.4	6.1	5.4	5.3	6.5	6.0	6.3			
	カルシウム・マグネシウム等(硬度)	≦300	1	---	47	---	---	35	---	---	42	---	---	30	---			
目	蒸 発 残 留 物	≦500	1	---	70	---	---	54	---	---	79	---	42	---				
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	<	---	---	---	---				
	ジエオスミン	≦0.00001	0.000001	---	---	---	---	---	---	<	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	<	---	---	---	---				
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	<	---	---	---	---				
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	<	---	---	---	---				
	有機物等(全有機炭素(TOC)量)	≦3	0.3	---	<	<	<	<	<	<	<	<	<	<				
	pH 値	5.8～8.6	---	6.6	8.3	6.5	6.5	6.4	6.4	6.5	6.4	6.5	6.6	6.6	6.6			
	味	異常でない	---	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし			
	臭 気	異常でない	---	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし			
色 度 (度)	≦5	0.5	<	<	<	<	<	<	<	<	<	<	<	<				
	濁 度 (度)	≦2	0.2	<	<	<	<	0.2	<	<	<	<	<	<				
残 留 塩 素	≧0.1	0.1	0.5	0.5	0.3	0.2	0.5	0.3	0.1	0.4	0.3	0.5	0.2	0.1				

折立地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名		施 設 名 称		折立地区 簡易水道												令和 6年 4月 〜 令和 7年 3月		
採 日	水 質 基 準	下 限 値	4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日				
天 気			晴	曇	晴	晴	晴	晴	雨	曇	曇	雪	雨	曇				
水 温 (℃)			12.0	13.2	17.5	17.0	19.0	23.0	22.5	18.5	15.0	9.3	7.2	8.5				
水 質	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	0	0	0	0	1	0	0	0	1	1				
	大 腸 菌	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出				
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	<	---	---	---	---				
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	<	---	---	---	---				
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---				
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	0.002	---	0.002	---	---	0.001	---				
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	<	---	<	---	---	<	---				
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---				
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.60	---	---	0.31	---	0.34	---	---	0.37	---				
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	<	---	---	<	---				
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	<	---	---	---	---				
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	<	---	---	---	---				
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	<	---	---	---	---				
	質 量	1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	<	---	---	---	---			
ジ ク ロ ロ メ タ ン		≦0.02	0.001	---	---	---	---	---	---	<	---	---	---	---				
テトラクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
トリクロロエチレン		≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
ベ ン ゼ ン		≦0.01	0.001	---	---	---	---	---	---	<	---	---	---	---				
塩 素 酸		≦0.6	0.06	---	<	---	---	<	---	<	---	---	<	---				
ク ロ ロ 酢 酸		≦0.02	0.002	---	<	---	---	<	---	<	---	---	<	---				
ク ロ ロ ホ ル ム		≦0.06	0.001	---	<	---	---	<	---	<	---	---	<	---				
ジ ク ロ ロ 酢 酸		≦0.03	0.002	---	<	---	---	<	---	<	---	---	<	---				
ジ ブ ロ モ ク ロ ロ メ タ ン		≦0.1	0.001	---	0.002	---	---	<	---	<	---	---	<	---				
臭 素 酸		≦0.01	0.001	---	<	---	---	<	---	<	---	---	<	---				
総トリハロメタン		≦0.1	0.001	---	0.003	---	---	<	---	<	---	---	<	---				
トリクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	<	---	---	<	---				
ブ ロ モ ジ ク ロ ロ メ タ ン		≦0.03	0.001	---	0.001	---	---	<	---	<	---	---	<	---				
ブ ロ モ ホ ル ム		≦0.09	0.001	---	<	---	---	<	---	<	---	---	<	---				
基 準		ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	<	---	---	<	---			
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	<	---	---	---	---				
	アルミニウム及びその化合物	≦0.2	0.01	---	0.02	---	---	0.01	---	0.03	---	---	0.04	---				
	鉄 及 び そ の 化 合 物	≦0.3	0.01	---	<	---	---	<	---	0.01	---	---	0.02	---				
	銅 及 び そ の 化 合 物	≦1.0	0.01	---	---	---	---	---	---	<	---	---	---	---				
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	6.1	---	---	---	---				
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	<	---	---	---	---				
	塩 化 物 イ オ ン	≦200	1.0	6.2	6.9	6.4	5.9	6.2	6.3	5.9	5.7	6.5	6.9	7.3				
	カルシウム・マグネシウム等(硬度)	≦300	1	---	48	---	---	49	---	---	48	---	45	---				
	蒸 発 残 留 物	≦500	1	---	62	---	---	76	---	---	82	---	74	---				
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	<	---	---	---	---				
	ジ エ オ ス ミ ン	≦0.00001	0.000001	---	---	---	---	---	---	<	---	---	---	---				
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	<	---	---	---	---				
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	<	---	---	---	---				
	フ ェ ノ ー ル 類	≦0.005	0.0005	---	---	---	---	---	---	<	---	---	---	---				
	項 目	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	0.3	<	<	<			
pH 値		5.8〜8.6		8.3	7.4	8.3	8.0	8.0	7.8	8.1	8.1	8.3	8.2	8.2				
味		異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
臭 気		異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
色 度 (度)		≦5	0.5	1.5	<	<	1.9	<	<	<	5.3	0.5	0.5	0.7				
濁 度 (度)		≦2	0.2	0.2	<	<	0.2	<	<	<	0.6	<	<	<				
残 留 塩 素		≧0.1	0.1	0.2	0.3	0.4	0.2	0.3	0.2	0.3	0.2	0.1	0.2	0.2				
臭 味		異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし				
色 度 (度)		≦5	0.5	1.5	<	<	1.9	<	<	<	5.3	0.5	0.5	0.7				
濁 度 (度)		≦2	0.2	0.2	<	<	0.2	<	<	<	0.6	<	<	<				
残 留 塩 素	≧0.1	0.1	0.2	0.3	0.4	0.2	0.3	0.2	0.3	0.2	0.1	0.2	0.2					

東天田地区 簡易水道

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

目 名		施 設 名 称		東天田地区 簡易水道											令和 6年 4月 ～ 令和 7年 3月	
採 水	日	水質基準	下限値	4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日	
	天 気			晴	曇	晴	晴	晴	晴	雨	曇	曇	雪	雨	曇	
水	温 (℃)			11.5	15.5	18.5	22.5	25.0	26.5	22.7	17.0	12.0	3.0	4.2	6.0	
	一 般 細 菌 (集 落 数 /ml)	≦100	0	0	6	0	0	1	0	1	0	0	0	0	0	
水	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	<	---	---	---	---	
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	<	---	---	---	---	
	セ レ ン 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	
	鉛 及 び そ の 化 合 物	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---	
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	<	---	---	<	---	---	<	---	
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	<	---	---	<	---	---	<	---	
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	---	---	---	<	---	---	<	---	---	<	---	
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.95	---	---	0.91	---	---	0.84	---	---	0.93	---	
	フッ素及びその化合物	≦0.8	0.05	---	<	---	---	<	---	---	<	---	---	<	---	
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	<	---	---	---	---	
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	<	---	---	---	---	
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---	
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	<	---	---	---	---	
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	<	---	---	---	---	
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---	
	質	ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	---	<	---	---	---	---
塩 素 酸		≦0.6	0.06	---	<	---	---	<	---	---	<	---	---	0.07	---	
ク ロ ロ 酢 酸		≦0.02	0.002	---	<	---	---	<	---	---	<	---	---	<	---	
ク ロ ロ ホ ル ム		≦0.06	0.001	---	<	---	---	<	---	---	<	---	---	<	---	
ジ ク ロ ロ 酢 酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---	
ジ ブ ロ モ ク ロ ロ メ タ ン		≦0.1	0.001	---	0.001	---	---	<	---	---	0.002	---	---	<	---	
臭 素 酸		≦0.01	0.001	---	<	---	---	<	---	---	<	---	---	<	---	
総トリハロメタン		≦0.1	0.001	---	0.002	---	---	<	---	---	0.004	---	---	<	---	
トリクロロ酢酸		≦0.03	0.002	---	<	---	---	<	---	---	<	---	---	<	---	
ブ ロ モ ジ ク ロ ロ メ タ ン		≦0.03	0.001	---	<	---	---	<	---	---	<	---	---	<	---	
ブ ロ モ ホ ル ム		≦0.09	0.001	---	0.001	---	---	<	---	---	0.002	---	---	<	---	
ホルムアルデヒド		≦0.08	0.005	---	<	---	---	<	---	---	<	---	---	<	---	
亜鉛及びその化合物		≦1.0	0.01	---	---	---	---	---	---	---	0.03	---	---	---	---	
アルミニウム及びその化合物		≦0.2	0.01	---	0.02	---	---	0.02	---	---	<	---	---	0.04	---	
鉄 及 び そ の 化 合 物		≦0.3	0.01	---	<	---	---	<	---	---	<	---	---	0.02	---	
銅 及 び そ の 化 合 物		≦1.0	0.01	---	---	---	---	---	---	---	0.05	---	---	---	---	
基		ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	7.0	---	---	---	---
		マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	<	---	---	---	---
		塩 化 物 イ オ ン	≦200	1.0	8.0	7.8	7.8	7.3	7.8	7.8	7.7	7.5	7.5	7.7	8.1	8.8
	カルシウム・マグネシウム等(硬度)	≦300	1	---	60	---	---	63	---	---	63	---	---	58	---	
	蒸 発 残 留 物	≦500	1	---	81	---	---	84	---	---	96	---	---	74	---	
	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	<	---	---	---	---	
	ジ エ オ ス ミ ン	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---	
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	<	---	---	---	---	
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	<	---	---	---	---	
	フ ェ ノ ール 類	≦0.005	0.0005	---	---	---	---	---	---	---	<	---	---	---	---	
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<	
	pH 値	5.8～8.6		8.1	8.3	8.1	8.0	8.0	7.8	7.9	8.0	8.0	8.1	8.1	8.1	
	臭 味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	
	色 度 (度)	≦5	0.5	<	<	1.0	2.4	<	<	<	<	<	1.5	<	<	
	濁 度 (度)	≦2	0.2	<	<	<	0.3	<	<	0.2	<	<	0.3	<	<	
	残 留 塩 素	≧0.1	0.1	0.3	0.3	0.2	0.3	0.3	0.3	0.2	0.2	0.1	0.2	0.3	0.3	0.3

西天田地区 飲料供給施設

※ “<”は下限値未満 “—”は未検査を表す。単位は記載のない限り“mg/L”とする。

項 目 名			施 設 名 称		西天田地区 飲料供給施設											令和 6年 4月 〜 令和 7年 3月		
採 水 日			水質基準		下限値		4月10日	5月9日	6月5日	7月18日	8月7日	9月4日	10月3日	11月7日	12月4日	1月9日	2月17日	3月12日
天 気							晴	曇	晴	晴	晴	晴	雨	曇	曇	雪	雨	曇
水 温 (℃)							11.0	14.0	18.0	23.6	24.8	25.5	22.6	16.5	11.0	3.0	3.5	3.2
水	一 般 細 菌 (集 落 数 /mL)	≦100	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	大 腸 菌	不検出		不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出	不検出
	カドミウム及びその化合物	≦0.003	0.0003	---	---	---	---	---	---	---	---	---	---	<	---	---	---	---
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---	---	---	---	---	---	---	---	---	<	---	---	---	---
	セレン及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	---	---	<	---	---	---	---
	鉛及びその化合物	≦0.01	0.001	---	---	---	---	---	---	---	---	---	---	<	---	---	---	---
	ヒ素及びその化合物	≦0.01	0.001	---	0.003	---	---	---	0.002	---	---	---	---	0.003	---	---	0.002	---
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	---	<	---	---	---	<	---	---	---	---	<	---	---	<	---
	亜 硝 酸 態 窒 素	≦0.04	0.004	---	<	---	---	---	<	---	---	---	---	<	---	---	<	---
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	<	---	---	---	<	---	---	---	---	<	---	---	<	---
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	---	0.17	---	---	0.19	---	---	---	---	0.24	---	---	---	0.23	---
	フッ素及びその化合物	≦0.8	0.05	---	0.06	---	---	---	<	---	---	---	0.06	---	---	---	<	---
	ホウ素及びその化合物	≦1.0	0.1	---	---	---	---	---	---	---	---	---	<	---	---	---	---	---
	四 塩 化 炭 素	≦0.002	0.0002	---	---	---	---	---	---	---	---	---	<	---	---	---	---	---
	1,4- ジ オ キ サ ン	≦0.05	0.005	---	---	---	---	---	---	---	---	---	<	---	---	---	---	---
	1,2-ジクロロエチレン及び1,1,2,2-ジクロロエチレン	≦0.04	0.004	---	---	---	---	---	---	---	---	---	<	---	---	---	---	---
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	---	---	---	---	---	---	---	---	---	<	---	---	---	---	---
	テトラクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	---	<	---	---	---	---	---
	トリクロロエチレン	≦0.01	0.001	---	---	---	---	---	---	---	---	---	<	---	---	---	---	---
ベ ン ゼ ン	≦0.01	0.001	---	---	---	---	---	---	---	---	---	<	---	---	---	---	---	
基	塩 素 酸	≦0.6	0.06	---	0.06	---	---	<	---	---	---	<	---	<	---	---	0.07	---
	ク ロ ロ 酢 酸	≦0.02	0.002	---	<	---	---	<	---	---	---	<	---	<	---	---	<	---
	ク ロ ロ ホ ル ム	≦0.06	0.001	---	<	---	---	<	---	---	---	<	---	<	---	---	<	---
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	<	---	---	<	---	---	---	<	---	<	---	---	<	---
	ジ ブ ロ モ ク ロ ロ メ タ ン	≦0.1	0.001	---	<	---	---	0.001	---	---	---	0.001	---	---	---	---	<	---
	臭 素 酸	≦0.01	0.001	---	<	---	---	<	---	---	---	<	---	<	---	---	<	---
	総トリハロメタン	≦0.1	0.001	---	<	---	---	0.003	---	---	---	0.001	---	---	---	---	<	---
	トリクロロ酢酸	≦0.03	0.002	---	<	---	---	<	---	---	---	<	---	<	---	---	<	---
	プロモジクロロメタン	≦0.03	0.001	---	<	---	---	0.001	---	---	---	<	---	<	---	---	<	---
	プ ロ モ ホ ル ム	≦0.09	0.001	---	<	---	---	0.001	---	---	---	<	---	<	---	---	<	---
項	ホルムアルデヒド	≦0.08	0.005	---	<	---	---	<	---	---	---	<	---	<	---	---	<	---
	亜鉛及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	---	<	---	<	---	---	---	---
	アルミニウム及びその化合物	≦0.2	0.01	---	<	---	---	<	---	---	---	<	---	<	---	---	<	---
	鉄及びその化合物	≦0.3	0.01	---	<	---	---	0.02	---	---	---	0.01	---	---	---	---	0.03	---
	銅及びその化合物	≦1.0	0.01	---	---	---	---	---	---	---	---	0.02	---	---	---	---	---	---
	ナトリウム及びその化合物	≦200	1.0	---	---	---	---	---	---	---	---	10.0	---	---	---	---	---	---
	マンガン及びその化合物	≦0.05	0.005	---	---	---	---	---	---	---	---	<	---	---	---	---	---	---
	塩 化 物 イ オ ン	≦200	1.0	6.7	6.9	6.9	6.2	6.5	6.9	6.8	6.3	6.4	6.5	6.9	7.6			
	カルシウム・マグネシウム等(硬度)	≦300	1	---	102	---	---	103	---	---	---	105	---	---	95	---		
	蒸 発 残 留 物	≦500	1	---	140	---	---	125	---	---	---	146	---	---	112	---		
目	陰イオン界面活性剤	≦0.2	0.02	---	---	---	---	---	---	---	---	<	---	<	---	---	---	---
	ジェオスミン	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	<	---	---	---	---
	2-メチルイソボルネオール	≦0.00001	0.000001	---	---	---	---	---	---	---	---	<	---	<	---	---	---	---
	非イオン界面活性剤	≦0.02	0.005	---	---	---	---	---	---	---	---	<	---	<	---	---	---	---
	フェノール類	≦0.005	0.0005	---	---	---	---	---	---	---	---	<	---	<	---	---	---	---
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<	<	<	<	<	<	<	<	<	<	<	<	<	<
	pH 値	5.8〜8.6		7.4	7.7	7.6	7.4	7.6	7.7	7.7	7.5	7.5	7.1	7.4	7.2			
	味	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし
	臭 気	異常でない		異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし	異常なし
	色 度 (度)	≦5	0.5	<	<	1.7	<	<	<	<	<	<	<	<	<	<	<	<
濁 度 (度)	≦2	0.2	<	<	0.2	<	<	<	<	<	<	<	<	<	<	<	<	
残 留 塩 素	≧0.1	0.1	0.2	0.2	0.2	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.4	0.3		