

項 目 名		水質基準	下限値	4月14日	5月19日										最大値	最小値	平均値
水	水 温（℃）			13.9	19.7										19.7	13.9	16.8
	一 般 細 菌（集 落 数 /ml）	≦100	0	0	0										0	0	0
	大 腸 菌	不検出		不検出	不検出										不検出	不検出	不検出
	カドミウム及びその化合物	≦0.003	0.0003	<	<										<	<	<
	水 銀 及 び そ の 化 合 物	≦0.0005	0.00005	---	---										---	---	---
	セ レ ン 及 び そ の 化 合 物	≦0.01	0.001	<	<										<	<	<
	鉛 及 び そ の 化 合 物	≦0.01	0.001	<	<										<	<	<
	ヒ 素 及 び そ の 化 合 物	≦0.01	0.001	<	<										<	<	<
	六 価 ク ロ ム 化 合 物	≦0.02	0.001	<	<										<	<	<
	亜 硝 酸 態 窒 素	≦0.04	0.004	<	<										<	<	<
	シアン化物イオン及び塩化シアン	≦0.01	0.001	---	---										---	---	---
	硝酸態窒素及び亜硝酸態窒素	≦10	0.10	0.48	0.42										0.48	0.42	0.45
	フッ素及びその化合物	≦0.8	0.05	<	<										<	<	<
	ホウ素及びその化合物	≦1.0	0.1	<	<										<	<	<
質	四 塩 化 炭 素	≦0.002	0.0002	<	<										<	<	<
	1,4- ジ オ キ サ ン	≦0.05	0.005	<	<										<	<	<
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≦0.04	0.004	<	<										<	<	<
	ジ ク ロ ロ メ タ ン	≦0.02	0.001	<	<										<	<	<
	テトラクロロエチレン	≦0.01	0.001	<	<										<	<	<
	トリクロロエチレン	≦0.01	0.001	<	<										<	<	<
	ベ ン ゼ ン	≦0.01	0.001	<	<										<	<	<
	塩 素 酸	≦0.6	0.06	---	---										---	---	---
	ク ロ ロ 酢 酸	≦0.02	0.002	---	---										---	---	---
	ク ロ ロ ホ ル ム	≦0.06	0.001	0.003	0.004										0.004	0.003	0.003
	ジ ク ロ ロ 酢 酸	≦0.03	0.002	---	---										---	---	---
	ジブロモクロロメタン	≦0.1	0.001	0.002	0.002										0.002	0.002	0.002
	臭 素 酸	≦0.01	0.001	---	---										---	---	---
	総トリハロメタン	≦0.1	0.001	0.008	0.009										0.009	0.008	0.009
基	トリクロロ酢酸	≦0.03	0.002	---	---										---	---	---
	ブ ロ モ ジ ク ロ ロ メ タ ン	≦0.03	0.001	0.003	0.003										0.003	0.003	0.003
	ブ ロ モ ホ ル ム	≦0.09	0.001	<	<										<	<	<
	ホルムアルデヒド	≦0.08	0.005	---	---										---	---	---
	亜鉛及びその化合物	≦1.0	0.01	<	<										<	<	<
	アルミニウム及びその化合物	≦0.2	0.01	<	<										<	<	<
	鉄 及 び そ の 化 合 物	≦0.3	0.01	<	<										<	<	<
	銅 及 び そ の 化 合 物	≦1.0	0.01	<	<										<	<	<
	ナトリウム及びその化合物	≦200	1.0	4.9	4.8										4.9	4.8	4.8
	マンガン及びその化合物	≦0.05	0.005	<	<										<	<	<
	塩 化 物 イ オ ン	≦200	1.0	6.0	5.4										6.0	5.4	5.7
	カルシウム・マグネシウム等(硬度)	≦300	1	33	32										33	32	32
	蒸 発 残 留 物	≦500	1	53	52										53	52	53
	陰イオン界面活性剤	≦0.2	0.02	---	---										---	---	---
準	ジ ェ オ ス ミ ン	≦0.00001	0.000001	<	<										<	<	<
	2-メチルイソボルネオール	≦0.00001	0.000001	<	<										<	<	<
	非イオン界面活性剤	≦0.02	0.005	---	---										---	---	---
	フ ェ ノ ー ル 類	≦0.005	0.0005	---	---										---	---	---
	有機物等(全有機炭素(TOC)量)	≦3	0.3	<	<										<	<	<
	pH 値	5.8～8.6		7.3	7.3										7.3	7.3	7.3
	味	異常でない		異常なし	異常なし										異常なし	異常なし	異常なし
	臭 気	異常でない		異常なし	異常なし										異常なし	異常なし	異常なし
	色 度（度）	≦5	0.5	<	<										<	<	<
	濁 度（度）	≦2	0.2	<	<										<	<	<
	残 留 塩 素	≧0.1	0.1	0.2	0.2										0.2	0.2	0.2
項																	
目																	

“<”は下限値未満、“---”は未検査を表す。
単位は、記載のない限り、mg/lとする。