

福井市脇三ヶ町 (田治島水系 西新配水池)

令和7年度

項目	名	水質基準	下限値	4月14日	5月19日	6月9日	7月7日	8月12日	9月8日	10月14日						最大値	最小値	平均値
水質基準	水温 (℃)			12.2	17.9	20.3	25.7	28.8	29.6	25.0						29.6	12.2	22.8
	一般細菌 (集落数 /ml)	≤100	0	0	0	0	0	0	0	0						0	0	0
	大腸菌	不検出		不検出						不検出	不検出	不検出						
	カドミウム及びその化合物	≤0.003	0.0003	---	---	---	---	---	---	---						---	---	---
	水銀及びその化合物	≤0.0005	0.00005	---	---	---	---	---	---	---						---	---	---
	セレン及びその化合物	≤0.01	0.001	---	---	---	---	---	---	---						---	---	---
	鉛及びその化合物	≤0.01	0.001	---	---	---	---	---	---	---						---	---	---
	ヒ素及びその化合物	≤0.01	0.001	---	---	---	---	---	---	---						---	---	---
	六価クロム化合物	≤0.02	0.001	---	---	---	---	---	---	---						---	---	---
	亜硝酸態窒素	≤0.04	0.004	---	---	---	---	---	---	---						---	---	---
	シアノ化物イオン及び塩化シアノ	≤0.01	0.001	---	---	---	---	---	---	---						---	---	---
	硝酸態窒素及び亜硝酸態窒素	≤10	0.10	0.67	0.67	0.64	0.57	0.51	0.47	0.44						0.67	0.44	0.57
	フッ素及びその化合物	≤0.8	0.05	---	---	---	---	---	---	---						---	---	---
	ホウ素及びその化合物	≤1.0	0.1	---	---	---	---	---	---	---						---	---	---
	四塩化炭素	≤0.002	0.0002	---	---	---	---	---	---	---						---	---	---
	1,4-ジオキサン	≤0.05	0.005	---	---	---	---	---	---	---						---	---	---
	シス-1,2-ジクロロエチレン及びトランス-1,2-ジクロロエチレン	≤0.04	0.004	---	---	---	---	---	---	---						---	---	---
	ジクロロメタン	≤0.02	0.001	---	---	---	---	---	---	---						---	---	---
	テトラクロロエチレン	≤0.01	0.001	---	---	---	---	---	---	---						---	---	---
	トリクロロエチレン	≤0.01	0.001	---	---	---	---	---	---	---						---	---	---
	ベンゼン	≤0.01	0.001	---	---	---	---	---	---	---						---	---	---
	塩素酸	≤0.6	0.06	---	---	---	---	---	---	---						---	---	---
	クロロ酢酸	≤0.02	0.002	---	---	---	---	---	---	---						---	---	---
	クロロホルム	≤0.06	0.001	0.002	0.002	0.003	0.003	0.004	0.004	0.004	0.004					0.004	0.002	0.003
	ジクロロ酢酸	≤0.03	0.002	---	---	---	---	---	---	---						---	---	---
	ジプロモクロロメタン	≤0.1	0.001	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003					0.003	0.002	0.002
	臭素酸	≤0.01	0.001	---	---	---	---	---	---	---						---	---	---
	総トリハロメタン	≤0.1	0.001	0.006	0.006	0.007	0.007	0.010	0.010	0.010	0.010					0.010	0.006	0.008
	トリクロロ酢酸	≤0.03	0.002	---	---	---	---	---	---	---						---	---	---
	ブロモジクロロメタン	≤0.03	0.001	0.002	0.002	0.002	0.002	0.003	0.003	0.003	0.003					0.003	0.002	0.002
	ブロモホルム	≤0.09	0.001	---	---	---	---	---	---	---						---	---	---
	ホルムアルデヒド	≤0.08	0.005	---	---	---	---	---	---	---						---	---	---
	亜鉛及びその化合物	≤1.0	0.01	---	---	---	---	---	---	---						---	---	---
	アルミニウム及びその化合物	≤0.2	0.01	---	---	---	---	---	---	---						---	---	---
	鉄及びその化合物	≤0.3	0.01	0.02	0.06	0.02	0.01	0.01	0.02	0.02	0.02					0.06	0.02	0.02
	銅及びその化合物	≤1.0	0.01	---	---	---	---	---	---	---						---	---	---
	ナトリウム及びその化合物	≤200	1.0	5.9	5.8	5.9	6.1	6.3	6.5	6.4						6.5	5.8	6.1
	マンガン及びその化合物	≤0.05	0.005	---	---	---	---	---	---	---						---	---	---
	塩化物イオン	≤200	1.0	7.6	6.8	6.7	6.7	6.4	6.2	6.0						7.6	6.0	6.6
	カルシウム・マグネシウム等(硬度)	≤300	1	39	38	39	40	42	45	44						45	38	41
	蒸発残留物	≤500	1	63	66	74	80	72	70	78						80	63	72
	陰イオン界面活性剤	≤0.2	0.02	---	---	---	---	---	---	---						---	---	---
	ジエオスマシン	≤0.00001	0.00001	---	---	---	---	---	---	---						---	---	---
	2-メチルイソボルネオール	≤0.00001	0.00001	---	---	---	---	---	---	---						---	---	---
	非イオン界面活性剤	≤0.02	0.005	---	---	---	---	---	---	---						---	---	---
	フェノール類	≤0.005	0.0005	---	---	---	---	---	---	---						---	---	---
	有機物等(全有機炭素(TOC)量)	≤3	0.3	---	---	---	---	---	---	---						---	---	---
	pH値	5.8~8.6		7.1	7.1	7.1	7.1	7.2	7.2	7.0						7.2	7.0	7.1
	味	異常でない		異常なし						異常なし	異常なし	異常なし						
	臭気	異常でない		異常なし						異常なし	異常なし	異常なし						
	色度(度)	≤5	0.5	---	---	---	---	---	---	---						---	---	---
	濁度(度)	≤2	0.2	---	---	---	---	---	---	---						---	---	---
	残留塩素	≥0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.1	0.2						0.2	0.1	0.2

"〈"は下限値未満、"---"は未検査を表す。

単位は、記載のない限り、mg/lとする。

(年)脇三ヶ No.1