

排水池～天日乾燥床 システムフロー

排水池

$$V = (\text{排水池}) 15.6 \times 2 \text{池} = 31.2$$

$$(\text{分水堰}) 1 \text{池} = 21.7 = 333.7 \text{ m}^3$$

排泥池

$$V = (\text{排泥池}) 31.5 \times 2 \text{池} = 63$$

$$(\text{分水堰}) 1 \text{池} = 5.6 = 68.6 \text{ m}^3$$

濃縮槽

$$V = 222.7 \times 2 \text{池} = 445.4 \text{ m}^3$$

天日乾燥床

$$16.6 \text{ m}^2 \times 1 \text{池} \quad 39.0 \text{ m}^2 \times 10 \text{池}$$

$$S = 4,066 \text{ m}^2$$

